

## **8. ALTERNATE ENERGY SOURCE**

### **8.1 Parallel Generation**

Subject to certain requirements, the Company will allow parallel generation. In general, automatic synchronizing must be provided by the Customer together with automatic prevention of any feed into UI's de-energized system. Please contact UI's Customer Engineering Department and obtain a copy of CL&P and UI's *"Guidelines for Generator Interconnection"*. This document provides detailed requirements along with the application form and is also available on our website at [www.uinet.com](http://www.uinet.com) in the *"About UI-Doing Business with UI"* section titled *"Customer Owned Generation"*. The preliminary application should be filed early in the planning process to obtain assistance and the necessary approvals.

### **8.2 Uninterruptible Power Supply (UPS)**

If this type of service is desired, it will be installed, owned, operated, and maintained by the Customer. The Customer must provide automatic prevention of any feed into UI's de-energized system. Please contact UI's Customer Engineering Department for guidance.