

**The United Illuminating Company
Residential Load Control Rider RLC**

Applies throughout the Company's Service Area.

Availability:

Service under this Rider is optional where the Customer's requirements for electric service include loads which have the potential to operate primarily during Off-Peak Hours, and automatic load control is both beneficial and desirable. To qualify for service under this rate, equipment must be of a size and design approved by the Company and must be installed in accordance with the Company's specifications.

Character of Service:

Service (i.e., normal installation and maintenance of the equipment) is provided for automatic load control including a load control center installed as a 100 Amp sub-panel of the Customer's main electric service which shall include a main disconnect, a double pole 20 amp breaker, two single pole 15 amp breakers, a 115V double outlet grounded receptacle and a load control device synchronized to the off-peak hours of the Customer's TOU rate.

Installation:

The Customer may designate any load equal to or less than the rated capacity of installed load control equipment. Normal installation of the load control center is within 15 feet of the Customer's main electric service panel and with unrestricted access. Connection of the designated load to the load center is the responsibility of the Customer. The Customer may elect to hire their own electrician to meet this criteria or if the Customer elects to use UI, the work will be charged at the Company's standard labor and material rates. These costs may be paid in one lump sum or three equal payments on the Customer's electric bill.

Terms and Conditions:

The Company's Terms and Conditions in effect from time to time are a part of this Addendum where not inconsistent with any specific provisions hereof.

Rate per Month:

Load Control Center Installed as Sub-Panel of Main Electric Service: \$4.85

Minimum Term of Service:

One Year.

Effective: January 1, 2007

**Effective January 1, 2007
Decision dated August 30, 2006
Docket 05-06-04 Supplemental Decision**