

The United Illuminating Company

Distributed Generation Rider DG

Applies throughout the Company's Service Area.

Availability:

“This Rider is available to Distributed Generation (DG) load associated with new, DG projects with a rating of not more than sixty-five megawatts that begin operation after July 21, 2005, whose capacity is available during peak periods. Emergency generation and other demand response projects do not qualify for this Rider. However, peaking units qualify for the waiver. This Rider waives the distribution demand ratchet provision of the customer's applicable firm service rate based on the portion of the customer's load that is normally served by the customer's DG unit, but not more than the customer's maximum metered load. The Department of Public Utility Control's decision dated March 27, 2006, in Docket No. 05-07-16, requires that each DG unit be separately metered for electric output, on a measured time-of-use basis, in order to verify the availability of each DG unit during periods of system peak demand. UI is responsible for installing meters on any DG unit that is interconnected to UI's Electric Distribution System. The customer is responsible for installing metering on DG units interconnected directly within the customer's electric distribution system. In either case, the DG customer is responsible for the cost associated with metering the output of their DG facility.”

Effective: March 27, 2006

***Effective March 27, 2006
Decision dated March 27, 2006
Docket No. 05-07-16***