

LEGEND
 ● 11-3-ASB-385A ASBESTOS SAMPLE LOCATION

THIS MAP IS COMPILED FROM A PLAN TITLED: "STATION "B" WAREHOUSE FLOOR SLAB REPLACEMENT, UNITED ILLUMINATING CO., ENGLISH STATION, NEW HAVEN, CONN., PREPARED BY WESTCOTT AND MAPES INC. NEW HAVEN, CONN., DATED 5-2-43, PROJ NO. 43060, DWG NO. 1, SEQ #3862".



Φ GEI Consultants, Inc.

PLAN PREPARED FOR
UNITED ILLUMINATING COMPANY
 ENGLISH STATION
 NEW HAVEN, CONNECTICUT

**PLAN MAP - ROOFING
 STATION B**



SCALE: NTS	DRN BY:
DATE: JAN 2000	99419

PLATE 21



EAST BRANCH MILL RIVER

WEST BRANCH MILL RIVER



LEGEND

● 11-3-ASB-385A	ASBESTOS SAMPLE LOCATION
■ 11-9-LBP-03	LEAD BASED PAINT SAMPLE LOCATION

THIS MAP IS COMPILED FROM A PLAN TITLED: "ENGLISH STATION-NEW HAVEN, CT, SITE REMEDIATION AND BULKHEAD REPAIR, SITE HISTORICAL GENERAL PLAN, UNITED ILLUMINATING CO., OCEAN AND COASTAL CONSULTANTS, INC., DATED 2-6-98, DWG NO. 97062-HGP-1".

GEI Consultants, Inc.

PLAN PREPARED FOR
UNITED ILLUMINATING COMPANY
 ENGLISH STATION
 NEW HAVEN, CONNECTICUT

SECONDARY STRUCTURES

SCALE: NTS	DRN BY:	PLATE 22
DATE: JAN 2000	99419	

APPENDIX C

2011 GEOQUEST INTERIOR PCB EQUIPMENT SURVEY RESULTS

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)
Sheet No. 1

SurveyNo.	Date	Description	Approximate Location
Main Floor- (second floor of old building and new addition, also known as Turbine Room)			
A-1	8-30-11	M-G Set	Main Floor- Turbine Hall
A-2	8-30-11	M-G Set	Main Floor- Turbine Hall
A-3	8-30-11	M-G Set	Main Floor- Turbine Hall
A-4	8-30-11	M-G Set	Main Floor- Turbine Hall
A-5	8-30-11	M-G Set	Main Floor- Turbine Hall
A-6	8-30-11	M-G Set	Main Floor- Turbine Hall
Lower Level- ground floor of the English Station (old and new buildings)			
D-1-5	8-30-11	5- Drums- Liquid, "Decon Water"	Lower Level (LL)- Ground Level
D-6	8-30-11	Drum- oil	LL Inside Turbine Shell
D-7	8-30-11	Drum	LL Crushed under stair well
D-8	8-30-11	Drum no label	LL By itself
D-9	8-30-11	Drum	LL Marked Well Water
D-10	8-30-11	Drum	LL On its side
D-11-13	8-30-11	Drums	LL On their sides, near middle (side to side) of LL.
ED (1)	8-30-11	Electric Device (ED), contains electrolytic capacitor	LL At end of old building, start of new addition.
ED-2	8-30-11	Oil Circuit Breaker FK-158-150 (9 gallons oil)	LL At start of new addition (northern section, west side)
ED-3	8-30-11	Oil Circuit Breaker (same as ED-2)	LL (southern section, west side)
D-14-15	8-30-11	Translucent Plastic Drums	LL (southern section, east side) near B-13
B-19	8-30-11	Small Motor	LL (northern section, east side)
B-20	8-30-11	Motor driven pump	LL (east side) near plant northern wall

DRAFT

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)

Sheet No. 2

SurveyNo.	Date	Description	Approximate Location
Gate Houses North and South- (also identified on some drawings as Screen Houses North and South)			
A-11	8-30-11	Motorized Pump	Gate House North
A-12	8-30-11	Motorized Pump	Gate House North
A-13	8-30-11	Large Winch	Gate House North
A-14	8-30-11	Large Winch	Gate House North
A-15	8-30-11	Large Motorized Pump	Gate House North
A-16	8-30-11	Tower Motor	Gate House North
A-17	8-30-11	Motorized Pump	Gate House South
A-18	8-30-11	Motorized Pump	Gate House South
A-19	8-30-11	Tower Motor	Gate House South
A-20	8-30-11	Tower Motor	Gate House South
A-21	8-30-11	Large Motorized Pump	Gate House South
Switch House (SH) - four and three story addition on western side of English Station, identified on drawings as "Switch House" and filled (numbers estimated to be in the hundreds) with metal cylinders, some with oil in the base (initial oil analysis indicates non-PCB), and small sealed transformer-like electric devices			
A-22	8-30-11	Motorized pump	SH upper level
A-23	8-30-11	Air Compressor Motor	SH upper level
A-24	8-30-11	Air Compressor Motor	SH upper level
A-25	8-30-11	Air Compressor Motor	SH upper level
A-26	8-30-11	Small Gearmotor	SH top level
Boiler Room - Lower Level - Old and New buildings			
D-16-49	8-31-11	34 Liquid Drums	Near north end of boiler room lower level western side
D-50	8-31-11	Liquid Drum	Slightly south of above drums

DRAFT

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)
Sheet No. 3

SurveyNo.	Date	Description	Approximate Location
D-51	8-31-11	Ash Drum	LL, western side, south of D-50
D-52	8-31-11	Drum - Degreaser	LL, western side, south end of old building
A-27	8-31-11	Motor Generator	LL, north of workshop, western side
A-28	8-31-11	Motor for Blower	LL, workshop, western side
A-29	8-31-11	Small Gearmotor	LL, workshop, western side
A-30	8-31-11	Compressor Motor	LL At start of new addition (northern section, east side)
A-31	8-31-11	Compressor Motor	LL, northern section, eastern side
A-32	8-31-11	Compressor Motor	LL, northern section, eastern side
A-33	8-31-11	Two Gearmotors	LL, northern section, eastern side
A-34	8-31-11	Large Motor (removed from gearbox)	LL, northern section, eastern side
A-35	8-31-11	Large Motor (removed from gearbox)	LL, northern section, eastern side
A-36	8-31-11	Two Blowermotors	LL, northern section, eastern side
P-1-4	8-31-11	Four Heavy Pumps	LL, northern section, eastern side
A-37	8-31-11	Two oil-filled Bearings	LL eastern side
A-38	8-31-11	Two oil-filled Bearings	LL eastern side
A-39	8-31-11	Two oil-filled Bearings	LL eastern side
A-40	8-31-11	Bearings on Motor, oil filled	LL eastern side
A-41	8-31-11	Bearings on Motor, oil filled	LL eastern side
A-42	8-31-11	Bearings on Motor, oil filled	LL eastern side
A-43	8-31-11	Bearings on Motor, oil filled	LL eastern side
ED-2	8-31-11	2- electrical devices w/PCB sticker (non-PCB)	LL eastern side, near northern end of building

DRAFT

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)

Sheet No. 4

DRAFT

SurveyNo.	Date	Description	Approximate Location
D-53-72	8-31-11	19 Drums	LL, Bermed area- eastern side near northern end of building
Pails	8-31-11	11 5-gallon Pails	LL, Stored with D-53-72
A-44	8-31-11	2 Vertical Motors	LL, at northern wall of building
Main Floor - Boiler Room - Old Plant (MFBR)			
C-1	9-6-11	Motor	MFBR, western side at northern wall,
C-2	9-6-11	Valve operator motor & gearbox	MFBR, western side
C-3	9-6-11	Valve operator motor & gearbox	MFBR, western side
C-4	9-6-11	Valve operator motor & gearbox	MFBR, western side
C-5	9-6-11	Circulator-pump motor	MFBR, western side
C-6	9-6-11	Circulator-pump motor	MFBR, western side
C-7	9-6-11	Valve operator motor & gearbox	MFBR, western side
C-8	9-6-11	Valve operator motor & gearbox	MFBR, western side
C-9	9-6-11	Valve operator motor & gearbox	MFBR, western side
C-10	9-6-11	Boiler Controls, one per boiler	MFBR
C-11	9-6-11	Boiler Controls, one per boiler	MFBR
C-12	9-6-11	Boiler Controls, one per boiler	MFBR
C-13	9-6-11	Boiler Controls, one per boiler	MFBR
C-14	9-6-11	Boiler Controls, one per boiler	MFBR
C-15	9-6-11	Boiler Controls, one per boiler	MFBR
C-16	9-6-11	Boiler Controls, one per boiler	MFBR
C-17	9-6-11	Boiler Controls, one per boiler	MFBR

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)
Sheet No. 5

SurveyNo.	Date	Description	Approximate Location
C-18	9-6-11	Boiler Controls, one per boiler	MFBR
C-19	9-6-11	Boiler Controls, one per boiler	MFBR
C-20	9-6-11	Boiler Controls, one per boiler	MFBR
C-21	9-6-11	Boiler Controls, one per boiler	MFBR
C-22	9-6-11	Motor	MFBR, east wall, middle
<p>Each of the 12 boilers has a series of hand operated gear box valve actuators mounted on the upper and lower levels of each end of the boiler; also, between the two rows of boilers (mounted above the boilers) is a series of valve operator motor & gearboxes similar to C-2 above (one for each of the adjacent boilers).</p>			
Main Floor - Boiler Room - New Plant- northern section			
C-23-25	9-6-11	3- Motor-Generator Sets	MBFR, northern section
C-26	9-6-11	Motorized gearbox	MBFR, northern section
C-27	9-6-11	Motorized gearbox	MBFR, northern section
C-28	9-6-11	Pump Motor	MBFR, northern section
C-29	9-6-11	Pump Motor	MBFR, northern section
Main Floor - Boiler Room - New Plant- southern section			
C-30-32	9-6-11	3- Motor-Generator Sets	MBFR, southern section
C-33	9-6-11	Motorized Valve Actuator	MBFR, southern section
C-34	9-6-11	Motorized Valve Actuator	MBFR, southern section
C-35	9-6-11	Motorized Valve Actuator	MBFR, southern section
C-36-37	9-6-11	Motorized Gearboxes	MBFR, southern section
C-38	9-6-11	Transformer	MBFR, southern section
C-39-40	9-6-11	Pump Motor	MBFR, southern section
C-41	9-6-11	Gear Motor	MBFR, southern section

DRAFT

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)

Sheet No. 6

SurveyNo.	Date	Description	Approximate Location
Lower Level- (ground floor of old building and new addition, also known as Turbine Room)			
B-1-3	8-30-11	Pump	LL, Turbine Hall
B-4	8-30-11	Gearmotor and pump	LL, Turbine Hall
B-5-6	8-30-11	Pump	LL, Turbine Hall
B-7	8-30-11	Gear Box	LL, new building, northern section, east
B-8	8-30-11	Pump	LL, new building, northern section, east
B-9	8-30-11	4 Gearmotors	LL, new building, northern section, east
B-10	8-30-11	Boiler Pump Unit	LL, new building, northern section, east
B-11	8-30-11	2 Motor Pump Assemblies	LL, new building, northern section, east
B-12	8-30-11	Oil Filter Tank and Pumps	LL, new building, southern section, east
B-13	8-30-11	Pressure Controller System	LL, new building, southern section, east
B-14	8-30-11	Oil Reservoir	LL, new building, southern section, east
B-15	8-30-11	2 Pump Assemblies	LL, new building, southern section, east
B-16	8-30-11	Control Box	LL, new building, southern section, east
B-17	8-30-11	Gearmotor	LL, new building, southern section, east
B-18	8-30-11	Motor	LL, new building, southern section, east
Switch House			
B-21	8-30-11	Lift	Switch House Main Level
B-22	8-30-11	Motor	Switch House Main Level
B-23	8-30-11	Motor	Switch House Main Level
B-25	8-30-11	Pump & Motor	Switch House Main Level
B-26	8-30-11	Air Handler Motor	Switch House Main Level

DRAFT

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)

Sheet No. 7

SurveyNo.	Date	Description	Approximate Location
Lower Level (Ground Floor) Boiler Room			
B-27	8-31-11	2 Drums	LL, at Northern End of Building
B-28	8-31-11	2 Motors	LL, at Northern End of Building
B-29	8-31-11	9 Tanks	LL, at Northern End of Building
B-30	8-31-11	Pump Assembly	LL, in western half of Boiler Room
B-31	8-31-11	Pump Assembly	LL, in western half of Boiler Room
B-32	8-31-11	Bearing Pump	LL, in western half of Boiler Room
B-33	8-31-11	Pump Assembly	LL, in western half of Boiler Room
B-34	8-31-11	Boiler Feed Pump	LL, in western half of Boiler Room
B-35	8-31-11	Boiler Feed Pump	LL, in western half of Boiler Room
B-36	8-31-11	Pump Assembly	LL, in western half of Boiler Room
B-37	8-31-11	2 Pumps	LL, in western half of Boiler Room
B-38	8-31-11	Gear Boxes	LL, in western half of Boiler Room
B-39	8-31-11	Gear Boxes	LL, in western half of Boiler Room
B-40	8-31-11	4 Gearmotors	LL, in western half of Boiler Room
B-41	8-31-11	4 Pumps	LL, in western half of Boiler Room, southern end of old building
Lower Level (Ground Floor) Boiler Room, New Building, Southern Section			
B-42	8-31-11	Pump	LL, new building, southern section
B-43	8-31-11	Metal Tank	LL, new building, southern section
B-44	8-31-11	Air Handling Gear Pump	LL, new building, southern section
Xfmrs	8-31-11	3 Large Transformers, Oil Filled, in concrete berm, #5,6, & 7	LL, new building, southern section

DRAFT

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)

Sheet No. 8

SurveyNo.	Date	Description	Approximate Location
B-45	8-31-11	Henly Press	Near eastern boiler room wall and Fuel Oil Room
B-46	8-31-11	3- Gear Motors	LL, new building, southern section
B-47	8-31-11	Many Valves mounted on walls of "Fuel Oil Room"	Fuel Oil Room
B-48	8-31-11	12 Drums (7- 30 gallon, 5- 55 gallon)	Ash Silo
Xfmrs	8-31-11	2 Large Transformers, Oil Filled, in concrete berm, #8 & 9	LL, new building, northern section
B-49	8-31-11	Metal Structure (Pump Enclosure?) with drain	LL, middle of old Boiler Room, eastern wall
New Section Level 3 through 9 (Level 10 & 11 appear to be inaccessible) consisting of two large boilers and related support equipment			
Level 3			
C-42	9-6-11	Gearmotor	Southern section
C-43	9-6-11	Gearmotor	Northern section
C-44	9-6-11	Gearmotor	Northern section
C-45	9-6-11	Pair of Gearmotor	Northern section
C-46	9-6-11	Pair of Gearmotors	Northern section
C-47	9-6-11	Motor	Northern section
C-48	9-6-11	Gearmotor	Northern section (actually on Level 5)
C-49	9-6-11	Blower Motor	Northern section (actually on Level 5)
C-50	9-6-11	Gearmotor	Southern section (actually on Level 5)
C-69	9-6-11	Pair of Gearmotors	Southern section
C-70	9-6-11	Pair of Gearmotors	Southern section
C-71	9-6-11	Pair of Pumpmotorw	Northern section
C-72	9-6-11	Compressor and Motor	Northern section

DRAFT

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)
Sheet No. 9

SurveyNo.	Date	Description	Approximate Location
C-73	9-6-11	Hand Actuator	Southern section
C-74	9-6-11	Compressor Motor	Southern section
C-75	9-6-11	Hand Actuator	Southern section
C-76	9-6-11	Motorized Gearbox	Southern section
C-77	9-6-11	Motorized Actuator	Northern section
Level 4			
Boiler So.	9-6-11	6 Actuators on north side & 6 Actuators on south side	Southern section
Boiler No.	9-6-11	6 Actuators on north side & 5 Actuators on south side	Northern section
C-68	9-6-11	Hand operated Actuator dripping oil	Southern section
Level 5			
C-65	9-6-11	Motorized Actuator	Northern section
C-66	9-6-11	Motorized Actuator	Southern section
C-67	9-6-11	Gearmotor	Southern section
Boiler So.	9-6-11	2 Actuators on north side & 2 Actuators on south side	Southern section
Boiler No.	9-6-11	2 Actuators on north side & 2 Actuators on south side	Northern section
Level 6			
C-48	9-6-11	Gearmotor	Northern section (also entered on Level 3 above)
C-49	9-6-11	Blower Motor	Northern section (also entered on Level 3 above)
C-50	9-6-11	Gearmotor	Southern section (also entered on Level 3 above)
C-60	9-6-11	Motor	Northern section
C-61	9-6-11	Pair of Vertical Pump Motors	Northern section

DRAFT

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)

Sheet No. 10

SurveyNo.	Date	Description	Approximate Location
C-62	9-6-11	Gearbox	Centered on northern and southern sections
C-63	9-6-11	Pair of Gearmotors	Twin Conveyors run length of old plant (access from Level 6, new bldg)
C-64	9-6-11	Pair of Vertical Pump Motors	Southern section
Level 7			
C-52	9-6-11	Blower Motor	Northern section
C-53	9-6-11	Blower Motor	Southern section
C-54	9-6-11	Blower Motor	Southern section
C-55	9-6-11	Blower Motor	Southern section
C-56	9-6-11	Blower Motor	Southern section
C-57	9-6-11	Blower Motor	Northern section
C-58	9-6-11	Blower Motor	Northern section
C-59	9-6-11	Blower Motor	Northern section
Level 8			
Hopper No.	9-6-11	6 Small Motors at base of each hopper	Northern section
Hopper So.	9-6-11	6 Small Motors at base of each hopper	Southern section
Level 9			
C-51	9-6-11	Elevator Gearmotor	Northern section
Machine Shop & Screen House (New Section)			
Pump Motors	9-21-11	2 Pump motors with oilers	Main Floor Screen House
Vertical Motors	9-21-11	2 Large Vertical Westinghouse Motors with oil lubrication systems	Main Floor Screen House
Electrolysis	9-21-11	Electrolysis System in oil tight panel with PCBs (labeled)	Main Floor Screen House

DRAFT

English Station - Interior Survey of Potential PCB Containing Equipment (Aug/Sep, 2011)
Quantity Break-down by Category

Category	Description	Quantity
M-G Set	A motor coupled to a generator on a common base. The motor, generator, or coupling may contain oil.	13
Motor (electric)	Older, larger motors above 15 Hp were often oil lubricated. Smaller, newer motors generally have sealed bearings.	27
Gearmotor	The gearbox of a gearmotor will most often contain oil.	48
Pump-motor	The pump of a pump-motor will often have oil lubrication.	52
Winch	Winches are often built around gearboxes which may contain oil lubrication.	2
Air Compressor	Air compressors often contains oil lubrication.	8
Oil filled bearings	Some bearings are separately lubricated with oil.	14
Actuator/valve operator	These are specialized gear boxes with either a hand operated input or an electric motor input or both. May contain oil.	46
Small transformers	Small, hermetically sealed transformers, contain a heat conducting fluid. Most are located in Switch House.	Many
Red Cylinders	Red Cylinders - 8 inches diameter, 24 inches long, partially filled with oil. Most are located in Switch House. Initial analysis of oil indicates non-PCB.	Many
Boiler controls	Electro-hydraulic control panels, may contain oil.	12
Miscellaneous	Un-categorized devices, may contain oil.	7
Drums - 55 gallon		95
Drums - 30 gallon		7
Pails - 5 gallon		11

DRAFT

APPENDIX D

BUILDING PHOTOGRAPHS



PHOTO 1 – 2nd Floor Boiler 1-12 Area – View of Boiler Ribs



PHOTO 2 – 2nd Floor Boiler 1-12 Area – Elevated Area between Boilers



PHOTO 3 – 1st Floor NW Hall – Facing South



PHOTO 4 – Coal Conveyor Level Area – Facing North



PHOTO 5 – 1st Floor BF Pump Area – Facing South



PHOTO 6 – 2nd Floor Boiler 1-12 Area – East Side – Facing South




PHOTO 7 – 2nd Floor Boiler 1-12 Area – West Side – Facing South



PHOTO 8 – 2nd Floor Boiler 1-12 Area – Center Area Between Boilers – Facing South



PHOTO 9 – 1st Floor Fan Room – Facing South



PHOTO 10 – 1st Floor – Former Temporary Oil Storage Area – Facing South



PHOTO 11 – Exterior – View of South Side of Boiler 14 Area



PHOTO 12 – Exterior – View of East Side of Boiler 14 Area



PHOTO 13 – Exterior – View of East Side of Boiler 13/14 Area



PHOTO 14 – Exterior – View of North Side of Boiler 14 Precipitator



PHOTO 15 – Exterior – View of Boiler 14 Stack



PHOTO 16 – Boiler 14 Area – 3rd Floor – Base of Coal Silo



PHOTO 17 – Boiler 14 Area – 5th Floor – Metal Condensate Storage Tank on South End



PHOTO 18 – Boiler 14 Area – 6th Floor – Metal Breeching



PHOTO 19 – Boiler 14 Area – 7th Floor – Fan Motor

APPENDIX E

**INSPECTION FOR HAZARDOUS BUILDING MATERIALS – BOILER 1-
12 INTERIOR (AUGUST 2018)**

REPORT

INSPECTION FOR HAZARDOUS BUILDING MATERIALS

**ENGLISH STATION
BOILER #1-12 INTERIOR
510 GRAND AVENUE
NEW HAVEN, CONNECTICUT**

Prepared for

THE UNITED ILLUMINATING COMPANY

180 Marsh Hill Road
Orange, Connecticut

Prepared by

TRC Environmental Corporation

Windsor, Connecticut

October 29, 2018

**INSPECTION FOR HAZARDOUS
BUILDING MATERIALS**

**ENGLISH STATION
BOILER #1-12 INTERIOR
510 GRAND AVENUE
NEW HAVEN, CONNECTICUT**

Prepared for

THE UNITED ILLUMINATING COMPANY

180 Marsh Road
Orange, Connecticut

Prepared by

TRC
Windsor, Connecticut

TRC Project No. 263951-0000-0000

October 29, 2018

TABLE OF CONTENTS

1.0	INTRODUCTION.....	1
1.1	Purpose.....	1
1.2	Description of Boiler #1-12 Area.....	2
2.0	SUMMARY OF FINDINGS	4
2.1	PCB Inspection.....	4
2.1.1	First Floor.....	6
2.1.2	Second Floor	7
2.1.3	Coal Conveyor Level & Upper Elevated Areas.....	7
2.2	Asbestos Inspection.....	7
2.2.1	First Floor.....	8
2.2.2	Second Floor	8
2.2.3	Coal Conveyor Level & Upper Elevated Areas.....	9
2.3	Lead/Miscellaneous.....	9
2.3.1	First Floor.....	10
2.3.2	Second Floor	10
2.3.3	Coal Conveyor & Upper Elevated Areas.....	10
3.0	CONCLUSIONS	12
3.1	PCBs.....	12
3.2	Asbestos	13
3.3	Lead/Miscellaneous.....	13

TABLES

Table 1	Bulk Sample Summary of Suspect Asbestos Containing Materials
Table 2	Inventory and Classifications of Asbestos Containing Materials (>1%)
Table 3	Confirmed Non-Asbestos Containing Materials
Table 4	Bulk Sample Summary of Suspect PCB Containing Materials
Table 5	Identified PCB Bulk Product Waste (> 50 ppm)
Table 6	Identified Excluded PCB Products (>1 ppm)
Table 7	Inventory of Additional Hazardous/Regulated Materials, Wastes and Items Identified
Table 8	Lead Containing Paint Measurement Summary

PHOTOS

ASBESTOS AND PCB INSPECTION FIGURES

Figure 1	First Floor
Figure 2	Second Floor
Figure 3	Coal Conveyor Level & Upper Elevated Areas Floor

APPENDICES

Appendix A	Laboratory Accreditations
Appendix B	Inspector Accreditations
Appendix C	Asbestos Bulk Sample Analysis Data & Chain of Custody Forms
Appendix D	PCB Laboratory Analysis Data & Chain Of Custody Forms
Appendix E	Previous Environmental Reports
	<ul style="list-style-type: none">• <i>GEI Asbestos and Hazardous Material Survey (12/1999)</i>

1.0 INTRODUCTION

TRC Environmental Corporation (TRC) of Windsor, Connecticut was retained by The United Illuminating Company, Inc. (UI) to conduct an inspection to identify asbestos-containing materials, polychlorinated biphenyl (PCB) constituents of construction materials, lead and mercury, and other hazardous materials from the interior of the Boiler #1-12 Area in the English Station building located at 510 Grand Avenue in the City of New Haven, Connecticut (the “Site”), as required under the Partial Consent Order COWSPCB 15-001 (PCO). This is one of several Reports for the Site that will be submitted by the Respondent per PCO Section B.1.b.

Inspections were conducted by Mr. Greg Kaczynski (CT DPH Asbestos Inspector License No. 000329) and Mr. Mark Kearney (CT DPH Asbestos Inspector License No. 000147), assisted by Mr. Carmen Jacko (CT DPH Asbestos Inspector License No. 000812), Mr. Dave Webster (CT DPH Asbestos Inspector License No. 000960), and Mr. Zachary Smith (CT DPH Asbestos Inspector License No. 000985), on various dates in February, March, May and June of 2018.

1.1 Purpose

The goal of this inspection and sampling program, defined in the PCO Section B.1.b. is as follows:

- identify, document, inventory and assess asbestos-containing materials; determine if such materials are friable, damaged, unstable and accessible or may be disturbed by other actions required by the Consent Order; and to determine how to conduct asbestos abatement in a manner that is necessary to comply with all applicable laws in connection with a plan of abatement for such materials in accordance with Section B.1.e.8. below;
- fully characterize PCB constituents of all caulk, paint, flooring, roofing, mastics, fireproofing, soundproofing, waterproofing, sealants and all other materials;
- sample PCBs consistent and in compliance with the requirements as set forth in 40 CFR Part 761 for PCBs;
- investigate the presence of lead and mercury; and

- identify non-hazardous and hazardous waste and other hazardous materials.

1.2 Description of Boiler #1-12 Area

English Station is located on the southern portion of the Site and has an approximate footprint of 100,000 square feet. English Station is constructed of brick and concrete with steel reinforcement. The northeastern portion of the Plant, which will be referred to as the “Boiler #1-12 Area”, is the original boiler house of the English Station Power Plant, which housed the older, low pressure boiler units (Boilers 1-12). The *interior* of the Boiler 1-12 Area was inspected for this report.

The sections of the Boiler #1-12 Area **included** in this report are the interior of the:

- First Floor – comprised of hallways, a fan room, storage room, bathroom areas, offices, former temporary oil storage area, lube oil room, fuel oil pump room #2, BF Pump Hall & Area and the gas cylinder room. Refer to Figure 1.
- Second Floor – which contains the twelve (12) low pressure boiler units. The ceiling in this area is approximately 50 feet high and access to the upper portions is limited to stairwells on the north and south end. Metal grated walkways throughout, and around the boilers, are considered unsafe. There is also a small concrete mezzanine above the west end of this floor. Refer to Figure 2.
- Coal Conveyor Level & Upper Elevated Areas – which are located above the second floor. These areas are accessible from the stairwell on the North end of the second floor. The coal conveyor level runs the length of the Boiler 1-12 area. Other upper elevated areas (Room 1, Room 2 and West & East Coal Bunker Mechanical Rooms) are all on the north end. Refer to Figure 3.

The Sections of the Boiler 1-12 Area which are **excluded** from this report are:

- Exterior roofs
- Exterior building façade components (windows, doors, joints, etc.)

- Building materials associated with windows and doors on the interior of the building envelope (these areas were sealed with poly sheeting as critical barriers at the time of the inspection)
- Floor drains and other areas located below the surface of the first floor.

These Sections will be addressed in separate report.

Asbestos abatement activities to remove accessible, damaged asbestos-containing materials in the building were in progress at the time of this inspection. This work was being conducted as part of the Interim Measures Project. This work was completed in the Boiler 1-12 area in May 2018, and the area was abated of all asbestos containing materials that are friable, damaged, unstable, and accessible or may be disturbed by other actions required by the PCO. In addition, all loose and flaking paints, caulks and glazing materials were removed during the abatement activities.

2.0 SUMMARY OF FINDINGS

2.1 PCB Inspection

The building investigation for Building Materials with the potential to contain PCBs was performed following techniques generally employed in the Building Sciences industry to identify, locate and sample homogeneous building materials (i.e., AHERA asbestos sampling guidelines). TRC inspectors conducted visual inspections throughout Boiler 1-12 to identify suspect materials (see list below). Sampling methodology involved collecting a minimum of three grab bulk samples per homogenous material type to refute PCB presence, per 40 CFR Part 761 Subpart R protocols. Collection of all bulk material samples was accomplished using clean, dedicated nitrile gloves, tools (cleaned with hexane) and by placing the material directly into clean, laboratory-supplied sample containers. All samples were labeled with a sample identification number, the date and time of collection and the selected laboratory analyses. All samples were delivered under chain-of-custody protocol to ConTest Analytical Laboratory in East Longmeadow, Massachusetts. Bulk building material product samples were analyzed at ConTest Analytical Laboratory utilizing USEPA Method 8082 (PCB) with EPA Method 3540C (Soxhlet extraction) as required by USEPA Region 1. A total of 79 homogeneous bulk building materials were sampled and analyzed for PCBs. Of the 79 homogeneous bulk building materials (paints, glazing and caulking, floor tile and mastics) only 2 were found to contain PCB's greater than 50 mg/kg (ppm):

- Orange paint (P38) on pump valves in the Fuel Oil Pump Room on the 1st floor.
- Silver/orange paint (P5) on the structural steel column in the Fan Room on the 1st floor.

Residual oil/oil staining was noticed on and around the orange painted pump valves (P38) and at other locations within the Fuel Oil Pump Room #2. For now, this paint will be classified as **PCB bulk product waste**; however, the characterization for liquid PCB releases (which has not been performed yet) in conjunction with the bulk building material sampling will ultimately determine the disposal characterization.

The silver/orange paint (P5) on structural steel is found throughout the first floor. Only 1 out of the original 8 - P5 samples collected was found to contain PCB's greater than 50 mg/kg (ppm) and this was sample P5F (113 ppm PCBs) collected in the Fan Room. An additional 6 bulk building material samples of the P5 paint were later collected in the Fan Room and of these samples, only a second sample (#P5J - 309 ppm PCBs) collected on the same column as P5F had PCB's greater than 50 mg/kg (ppm). Based on the two rounds of sampling of similar paints in this area, only the silver/orange paint (P5) on this column in the Fan Room will be classified as **PCB bulk product waste**. Future planned sampling of the Fan Room and specifically this column, will be performed to assess for possible liquid PCB releases that may have impacted various surfaces. If appropriate, the waste characterization may be modified if the source of the PCBs is from a liquid release.

Of the remaining 77 homogeneous bulk building materials (paints, glazing and caulking, floor tile and mastics) none were found to contain PCB's greater than 50 mg/kg (ppm). TSCA Regulation Section 761.3 – Definitions defines **Excluded PCB Products** “as PCB materials which appear at concentrations less than 50 ppm, including the products or source of products containing < 50 ppm concentration PCBs were legally manufactured, processed, distributed in commerce, or used before October 1, 1984.” This means that the building materials found on the interior of the Boiler 1-12 Area to contain PCBs > 1ppm and < 50 ppm are deemed **Excluded PCB Products** and are exempt from TSCA Regulation.

Only those building materials defined in Section 761.3 as **PCB bulk product waste** are covered by the TSCA Regulation. **PCB bulk product waste** means waste derived from manufactured products containing PCBs in a non-liquid state, at any concentration where the concentration at the time of designation for disposal was ≥ 50 ppm PCBs. **PCB bulk product waste** includes non-liquid bulk wastes or debris from demolition of buildings and other man-made structures manufactured, coated or serviced with PCBs.

Following completion of the Interim Measure Project in Boiler 1-12, all building materials (paints, caulks, glazings, etc.) were observed to be intact/not flaking. Sample descriptions and results are

presented in Table 4; Bulk Sample Summary of Suspect PCB Containing Materials. Material locations and quantities are presented in Table 5; Identified **PCB Bulk Product Waste** and Table 6; Identified **Excluded PCB Products**.

Investigative sampling for identification and characterization of liquid PCB releases within Boiler 1-12 was not performed at this time. This work will be planned and implemented under a separate Scope of Study for this area of the building.

The following is an area-by-area summary of identified PCB's in the building. PCB containing materials which are also ACM, if applicable, are noted in Table 5 & 6.

2.1.1 First Floor

The following materials were identified as **PCB Bulk Product Waste**:

- The orange paint (P38) on pump valves in the Fuel Oil Pump Room.
- The silver/orange paint (P5) on the structural steel column (center area) in the Fan Room.

The following materials were identified as **Excluded PCB Products**:

- The majority of wall surfaces (brick, CMU, block), structural steel (columns, beams, and trusses), concrete deck, concrete pads, metal motors, pumps and miscellaneous components were observed to be painted; all paints (with the exception of P38 and P5 - as noted above) were identified as **Excluded PCB Products**.
- The window glazing on interior metal windows in the Storage Room, BF Pump Area and BF Pump Hall.
- The door window glazing on doors off the NW and SW Hallways.
- The floor tile/mastic in the SW Hall Office. (*Removed as part of the Interim Measures Project*)

2.1.2 Second Floor

The following materials were identified as ***Excluded PCB Products***:

- The majority of wall surfaces (brick, CMU, block), structural steel (columns, beams, and trusses), brick/metal boiler walls/panels, concrete deck, concrete pads, metal motors and miscellaneous components were observed to be painted; all paints were identified as ***Excluded PCB Products***.
- The window glazing on interior metal windows in the Restroom
- The caulking on metal tanks on the West Mezzanine.
- The floor tile/mastic in the Restroom. (*Removed as part of the Interim Measures Project*).

2.1.3 Coal Conveyor Level & Upper Elevated Areas

The following materials were identified as ***Excluded PCB Products***:

- Some wall surfaces (brick, CMU, block) and miscellaneous components and the majority of structural steel (columns, beams, and trusses) were observed to be painted; all paints were identified as ***Excluded PCB Products***.
- The window glazing on interior metal windows/doors of Room 1.

2.2 Asbestos Inspection

Connecticut licensed/EPA-trained asbestos inspectors from TRC conducted visual inspections to evaluate the conditions of previously identified asbestos containing materials (ACM) on the interior building components in accordance with USEPA Asbestos Hazard Emergency Response Act (AHERA)/National Emissions Standard for Hazardous Air Pollutants (NESHAP) protocols. Sampling and analysis of suspect materials for the possible presence of asbestos was limited to materials that were not identified in previous inspection reports. Bulk samples of suspect materials not previously identified were collected, properly transferred using chain-of-custody forms, and brought to TRC's laboratory for analysis via polarized light microscopy (PLM) with visual area estimate (vae) techniques (EPA 600/R-93/116). No newly identified ACM has been identified

(from sampling), however, TRC has made the assumptions that interior boiler insulation components (boiler insulation, rib insulation, firebrick), transite board panels associated with switchgear, electrical & circuit boxes/panels, insulation components and wiring associated with switchgear, electrical & circuit boxes/panels, gaskets in piping systems and pipe insulation in walls are ACM. All other ACM's addressed in Table 2 were identified during prior inspections. Details of the asbestos survey can be found in Tables 1-3 and in this Asbestos Inspection Summary. The Previous Inspection Report, by GEI, can be found in Appendix E.

Table 1 is a summary of Asbestos bulk samples collected by TRC. Asbestos sampling data from a Previous Inspection Report (by GEI) utilized in this report can be found in Appendix E. In Table 2, TRC provided the location, quantity, AHERA/NESHAP categories and condition of all identified ACM in the Boiler 1-12 Area Interior. Table 3 lists the locations of non-ACM's (<1%) sampled by TRC.

The following is an area-by-area summary of observations related to existing asbestos-containing materials in the building.

2.2.1 First Floor

Transite board panels, insulation components and wiring associated with switchgear, electrical & circuit boxes/ panels were observed to be intact or damaged, but non-friable. Inaccessible pipe insulation is assumed to be in the walls of the Bathroom Area and the SW Hall Bathroom. Assumed pipe gaskets are considered to be intact.

2.2.2 Second Floor

Inaccessible suspect ACM (gasket & rope material on boiler doors, hatches and panels, boiler insulation, boiler brick insulation, boiler rib insulation, canvas pipe/hose wrap insulation & boiler pipe filler) are assumed on the interior of the Boilers. Transite board panels, insulation components and wiring associated with switchgear, electrical & circuit boxes/ panels were observed to be intact or damaged, but non-friable. Inaccessible pipe insulation is assumed to be in the walls of the

Lavatory and Restroom Areas. Assumed pipe gaskets are considered to be intact.

2.2.3 Coal Conveyor Level & Upper Elevated Areas

Transite board panels, insulation components and wiring associated with switchgear, electrical & circuit boxes/ panels were observed to be intact or damaged, but non-friable. Assumed pipe gaskets are considered to be intact.

2.3 Lead/Miscellaneous

TRC performed a Lead Containing Paint inspection of the Boiler 1-12 Area Interior using EPA-trained and State of Connecticut-licensed lead inspectors. The method used for the Lead Containing Paint inspection was an X-Ray Fluorescence (XRF) utilizing an on-site Niton spectrum analyzer. The XRF detector is a portable unit designed to make fast, accurate, non-destructive measurements of lead concentrations in dry painted surfaces with a detection limit down to 0.1 mg/cm². Representative measurements of the painted building components were conducted throughout the subject building areas to determine the general presence of any detectable levels of lead paint. Loose and flaking paints were removed as part of the Interim Measure Project and were made intact throughout the area. Detailed results of the lead containing paint screening can be found in Table 8.

A visual inspection of the Boiler 1-12 Area Interior was performed to identify and quantify any suspect PCB-containing transformers, fluorescent light ballasts, suspect mercury-containing fluorescent light lamps or thermostat switches. Any additional hazardous/regulated items identified were also inventoried, and includes: chlorofluorocarbon (CFC)-containing devices, universal waste, used electronics, batteries, on-site oils, drums, chemicals, storage tanks, staining, biological hazards, tires, etc. Hazardous materials identified at the site by the inspectors were reviewed by a Certified Hazardous Materials Manager (CHMM) to determine and classify the potential hazards of each material identified and the handling/disposal methods that are required.

2.3.1 First Floor

Low levels (<1.0 mg/cm²) of lead paint were identified on metal pipes, metal tanks, brick, CMU & block walls, metal motor components, concrete pads and metal door components in the First Floor. Higher levels (>1.0 mg/cm²) of lead paint were identified on metal structural steel (columns, beams, etc.), metal door/window components, metal fan/motor components, brick walls in the First Floor. Detailed results of the lead containing paint screening can be found in Table 8.

A variety of other potentially hazardous/regulated materials, wastes or items were visually identified by TRC in this area as well. Refer to Table 7 for a complete list of these items, locations and potential hazards.

2.3.2 Second Floor

Low levels (<1.0 mg/cm²) of lead paint were identified on metal breeching, miscellaneous structural steel components, metal pipes, metal stairs, brick & block walls, brick & metal boiler components and metal door/window components in the Second Floor. Higher levels (>1.0 mg/cm²) of lead paint were identified on metal structural steel (columns, beams, etc.), metal stairs components, metal ducts, metal boiler plates, concrete walls/ceilings and brick walls in the Second Floor. Detailed results of the lead containing paint screening can be found in Table 8.

A variety of other potentially hazardous/regulated materials, wastes or items were visually identified by TRC in this area as well. Refer to Table 7 for a complete list of these items, locations and potential hazards.

2.3.3 Coal Conveyor & Upper Elevated Areas

Low levels (<1.0 mg/cm²) of lead paint were identified on brick walls and metal piping, duct and railing in the Coal Conveyor & Upper Elevated Areas. Higher levels (>1.0 mg/cm²) of lead paint were identified on metal windows, doors and structural steel (columns, beams, etc.) in the Coal Conveyor & Upper Elevated Areas. Detailed results of the lead containing paint screening can be found in Table 8.

A variety of other potentially hazardous/regulated materials, wastes or items were visually identified by TRC in this area as well. Refer to Table 7 for a complete list of these items, locations and potential hazards.

3.0 CONCLUSIONS

In line with the requirements of the Partial Consent Order (PCO), TRC provides the following conclusions based upon review of previous reports, visual inspection, assessment, and review of laboratory data from samples collected by TRC in the Boiler 1-12 Area Interior.

3.1 PCBs

TRC conducted inspection and sampling to fully characterize PCB constituents of all paints, glazing and caulking, floor tile, mastics and all other suspect materials from the Boiler 1-12 Area Interior in order to comply with the requirements of the PCO. Identification and characterization of liquid PCB releases within Boiler 1-12, as stated at the end of Section 1 of this Report, is not included in these Conclusions.

Two building materials were identified as *PCB Bulk Product Waste*:

- Orange paint (P38) on pump valves in the Fuel Oil Pump Room on the 1st floor.
- Silver/orange paint (P5) on the structural steel column in the Fan Room on the 1st floor.

Both materials were identified to contain PCB's greater than 50 mg/kg (ppm) (Refer to Tables 4 & 5). As the liquid PCB release identification and characterization has not been performed yet, the ultimate characterization of these building materials will be determined once the characterization of liquid PCB releases is complete.

Of the remaining 77 homogeneous bulk building materials (paints, glazing and caulking, floor tile and mastics) sampled, none were found to contain PCB's greater than 50 mg/kg (ppm). The remaining building materials in Tables 4 and 6 of this report would be identified as *Excluded PCB Products*.

3.2 Asbestos

TRC conducted a thorough inspection to identify, document, inventory and assess asbestos-containing materials in the Boiler 1-12 Area Interior in order to comply with the requirements of the PCO.

TRC did not identify any asbestos-containing materials which required a response action per Section B.1.e.8. of the PCO which indicates that the Respondent (UI) “shall only be required to abate asbestos that is friable, damaged, unstable, and accessible or may be disturbed by other actions required by this Consent Order, and to determine how to conduct asbestos abatement in a manner that is necessary to comply with all applicable laws.” All ACM which may have required abatement was addressed during the Interim Measures Project (which was completed in the Boiler 1-12 Area Interior in May 2018). All remaining ACM is either intact, inaccessible or damaged, but non-friable.

In the event that the building owner renovates the building, they will be subject to State of Connecticut and EPA requirements to address those building materials identified/assumed as ACM.

3.3 Lead/Miscellaneous

TRC performed a Lead Containing Paint Inspection utilizing an XRF device, as well as a visual inspection to identify and quantify any additional hazardous/regulated items.

As described in Section 2.3 and detailed in Tables 7 and 8, a variety of lead paint and other miscellaneous hazardous/non-hazardous items and materials were identified at the site. It is worth noting that as a result of the Interim measures Project all of the loose and flaking paints were removed and the surfaces made intact prior to completion. As the extent of the PCO was to identify these items no further remedial actions for these items are required. In the event that the building owner renovates the building for occupancy, they may be subject to other State of Connecticut

requirements to address those paints identified as lead containing.

In addition the disposal materials containing lead based paints and other miscellaneous hazardous/non-hazardous items are subject to USEPA regulation under RCRA and may be subject to other state regulation and disposal facility permit requirements for management of these materials.

TABLES

**TABLE 1
BULK SAMPLE SUMMARY OF SUSPECT ASBESTOS CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Location	Homogeneous Material	% and Type Asbestos
6/26/18 - Bulk Sampling Data			
1	Second floor – West mezzanine	C1 – Caulk at seam of tanks	ND
2	Second floor – West mezzanine	C1 – Caulk at seam of tanks	ND
3	1 st floor - SW hall	DWG1 – Light gray hard door window glaze	ND
4	1 st floor - SW hall	DWG1 – Light gray hard door window glaze	ND
5	First floor – storage room	WG1 – Hard glaze and interior window	ND
6	First floor – storage room	WG1 – Hard glaze and interior window	ND
7	First floor – BF pump area center area	WG2 – Window glaze on interior metal frame windows	ND
8	First floor – BF pump area center area	WG2 – Window glaze on interior metal frame windows	ND
9	Second floor – restroom	WG3 – Interior glazing on interior metal frame windows (Note: One sample previously taken by GEI)	ND
10	First floor – BF pump area north end	WG5 – Tan/cream Window glaze on interior metal window	ND
11	First floor – BF pump area north end	WG5 – Tan/cream Window glaze on interior metal window	ND
12	Coal conveyor level – North	WG6 – Hard tan window glaze on interior window	ND
13	Coal conveyor level – North	WG6 – Hard tan window glaze on interior window	ND
7/27/18 - Bulk Sampling Data			
01	2 nd floor – Boiler 1-12 Area – North End	Terracotta block	ND
02	2 nd floor – Boiler 1-12 Area – North End	Terracotta block	ND
03	2 nd floor – Boiler 1-12 Area – North End	Terracotta block	ND

NA/PVA Not analyzed/positive via inseparable association with a confirmed positive ACM

NA/PS Not analyzed/positive stop, homogeneous to sample proven to contain asbestos

ND<1% Non-detected, less than 1%

NAD No asbestos detected

+ Although found to be negative by analysis, material is homogeneous to a determined ACM and therefore must be considered positive

1 NOB material; result confirmed by TEM analyses

* Quantified by PLM Point Counting techniques

**TABLE 2
INVENTORY AND CLASSIFICATIONS OF ASBESTOS CONTAINING MATERIALS (>1%)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

ACBM	Sampled-Assumed (mo/yr)	Location	AHERA Category	NESHAP Category	Damage Assessment Category	Estimated Quantity
Gasket & rope material on boiler doors, hatches and panels	Sampled 12/99 (GEI)	<u>2nd floor</u> – Boilers 1-12	TSI	Friable	Inaccessible	Unknown
Interior boiler rib insulation	Assumed 02/18	<u>2nd floor</u> – Boilers 1-12	TSI	Friable	Inaccessible	Unknown
Interior boiler firebrick insulation	Assumed 02/18	<u>2nd floor</u> – Boilers 1-12	TSI	Friable	Inaccessible	Unknown
Interior boiler insulation	Assumed 02/18	<u>2nd floor</u> – Boilers 1-12	TSI	Friable	Inaccessible	Unknown

AHERA Categories = thermal system insulation (TSI), surfacing material or miscellaneous

NESHAP Categories = friable, category I non-friable or category II non-friable

Friable = crumbled, pulverized or reduced to powder by hand pressure when dry

Category I Non-friable = packings, gaskets, resilient floor covering and asphalt roofing

Category II Non-friable = all non-friable that is not Category I

Damage Assessment Category: Indicates if identified ACM is friable, damaged, unstable and accessible OR may be disturbed by other actions required by Consent Order.

Previous Environmental Reports (GEI) referenced in this table can be found in Appendix E.

◆ Excluded PCB Product (> 1 ppm) or inseparable to adjacent Excluded PCB Product.

**TABLE 2
INVENTORY AND CLASSIFICATIONS OF ASBESTOS CONTAINING MATERIALS (>1%)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

ACBM	Sampled-Assumed (mo/yr)	Location	AHERA Category	NESHAP Category	Damage Assessment Category	Estimated Quantity
Canvas pipe/hose wrap insulation	Sampled 12/99 (GEI)	2 nd floor – Boilers 1-12 (firing mechanism – boiler panel side)	TSI	Friable	Inaccessible	Unknown
Boiler Pipe Filler	Sampled 12/99 (GEI)	2 nd floor – Boilers 1-12 (presumed to be in interior of boilers)	TSI	Friable	Inaccessible	Unknown
Transite board panels associated with switchgear, electrical & circuit boxes/panels	Assumed 02/18	<u>Throughout</u>	Miscellaneous	Category II Non-friable	Intact or Damaged/Non-friable	Unknown
Insulation components & wiring associated with switchgear, electrical & circuit boxes/panels	Assumed 02/18	<u>Throughout</u>	Miscellaneous	Category II Non-friable	Intact or Damaged/Non-friable	Unknown

AHERA Categories = thermal system insulation (TSI), surfacing material or miscellaneous

NESHAP Categories = friable, category I non-friable or category II non-friable

Friable = crumbled, pulverized or reduced to powder by hand pressure when dry

Category I Non-friable = packings, gaskets, resilient floor covering and asphalt roofing

Category II Non-friable = all non-friable that is not Category I

Damage Assessment Category: Indicates if identified ACM is friable, damaged, unstable and accessible OR may be disturbed by other actions required by Consent Order.

Previous Environmental Reports (GEI) referenced in this table can be found in Appendix E.

◆ Excluded PCB Product (> 1 ppm) or inseparable to adjacent Excluded PCB Product.

**TABLE 2
INVENTORY AND CLASSIFICATIONS OF ASBESTOS CONTAINING MATERIALS (>1%)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

ACBM	Sampled-Assumed (mo/yr)	Location	AHERA Category	NESHAP Category	Damage Assessment Category	Estimated Quantity
Pipe insulation in walls	Assumed 02/18	<u>1st floor</u> – bathroom area, SW hall-bathroom <u>2nd floor</u> – Restroom, Lavatory	TSI	Friable	Inaccessible	200 LF
Pipe gaskets	Assumed 02/18	Throughout building	Miscellaneous	Category II non-friable	Intact	Unknown

AHERA Categories = thermal system insulation (TSI), surfacing material or miscellaneous

NESHAP Categories = friable, category I non-friable or category II non-friable

Friable = crumbled, pulverized or reduced to powder by hand pressure when dry

Category I Non-friable = packings, gaskets, resilient floor covering and asphalt roofing

Category II Non-friable = all non-friable that is not Category I

Damage Assessment Category: Indicates if identified ACM is friable, damaged, unstable and accessible OR may be disturbed by other actions required by Consent Order.

Previous Environmental Reports (GEI) referenced in this table can be found in Appendix E.

◆ Excluded PCB Product (> 1 ppm) or inseparable to adjacent Excluded PCB Product.

TABLE 3
CONFIRMED NON-ASBESTOS CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT

Material	General Location
C1 – Caulk at seam of tanks	Second floor – West mezzanine on tank seams/joints
DWG1 – Light gray hard door window glaze ♦	First Floor – SW hall & NW Hall
WG1 – Hard glaze and interior window ♦	First floor – storage room (east wall)
WG2 – Window glaze on interior metal frame windows ♦	First floor – BF pump area center area
WG3 – Interior glazing on interior metal frame windows	Second floor – restroom
WG5 – Tan/cream Window glaze on interior metal window	First floor – BF pump area north end
WG6 – Hard tan window glaze on interior window	Coal conveyor level – North
Terracotta block	Second floor – North End

♦ Excluded PCB Product (> 1 ppm) or inseparable to adjacent Excluded PCB Product.

**TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
FT1A	2/21/18	FT1 – 9”x9” green floor tile ♦	1 st floor – SW Hall Office	2.7	No
FT1B	2/21/18		1 st floor – SW Hall Office	6.54	
FTM1A	2/21/18	FTM1 – black mastic associated with 9”x9” green floor tile ♦	1 st floor – SW Hall Office	6.93	No
FTM1B	2/21/18		1 st floor – SW Hall Office	5.5	
FT2A	2/28/18	FT2 – 12”x12” floor tile ♦	2 nd floor – Restroom	ND<0.092	No
FT2B	2/28/18		2 nd floor – Restroom	0.44	
FT2C	2/28/18		2 nd floor – Restroom	0.16	
FTM2A	2/28/18	Mastic associated with 12”x12” floor tile (FT2) ♦	2 nd floor – Restroom	10.9	No
FTM2B	2/28/18		2 nd floor – Restroom	1.06	
FTM2C	2/28/18		2 nd floor – Restroom	2.16	
P1A	2/16/18	P1 – silver/green paint on lower wall (0-6’)	1 st floor – NW Hall North	6.4	No
P1B	2/16/18		1 st floor – NW Hall Center	5.4	
P1C	2/16/18		1 st floor – NW Hall South	6.85	
P2A	2/16/18	P2 – silver paint on wall, (brick, CMU)	1 st floor – NW Hall North	3.19	No
P2B	2/16/18		1 st floor – NW Hall Center	4.8	
P2C	2/16/18		1 st floor – NW Hall South	8.8	
P2D	2/16/18		1 st floor – NE Hall North	3.74	
P3A	2/19/18	P3 – silver/grey paint on concrete ceiling & metal ceiling (under boilers)	1 st floor – NW Hall South	2.87	No
P3B	2/19/18		1 st floor – NW Hall North	3.04	
P3C	2/19/18		1 st floor – NW Hall Center	1.79	
P5A	2/16/18	P5 – silver/orange structural steel components (throughout upper portions & columns)	1 st floor – NW Hall Center	7	No
P5B	2/16/18		1 st floor – NW Hall South	10.9	
P5C	2/16/18		1 st floor – NE Hall South	5.14	
P5D	2/16/18		1 st floor - Bathroom	3.78	
P5E	2/19/18		1 st floor – NE Hall South	8.1	
P5F	2/21/18		1 st floor – Fan Room	113	

♦ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
P5G/P33	2/26/18	P5 – silver/orange structural (throughout upper portions & columns) P33 – white paint upper walls & entire South wall	1 st floor – Fuel Oil Pump Room #2	4	No
P5H	2/26/18	P5 – silver/orange paint on structural steel (throughout upper portions & columns)	1 st floor – Storage Room	4.3	No
P5I	3/28/18		1 st floor Fan Room – West wall	10.76	
P5J	3/28/18		1 st floor Fan Room – West wall	309	Yes
P5K	3/28/18		1 st floor Fan Room – East wall	6.42	No
P5L	3/28/18		1 st floor Fan Room – East wall	12.7	
P5M	3/28/18		1 st floor Fan Room – West wall	7.09	
P5N	3/28/18		1 st floor Fan Room – East wall	8.8	
P21D	3/28/18	P21 – yellow paint on brick walls (sampled adjacent to columns)	1 st floor Fan Room – West wall	7.6	No
P21E	3/28/18		1 st floor Fan Room – East wall	8.7	
P21F	3/28/18		1 st floor Fan Room – East wall	0.76	
01A	3/28/18	Oil stain on overhead pipe	1 st floor Fan Room – East wall	13.2	No
P6A	2/16/18	P6 – silver/green metal door & window framing (metal)	1 st floor – NW Hall North	8.9	No
P6B	2/26/18		1 st floor – SW Hall S door	4	
P6C	2/26/18		1 st floor – BF Pump Hall S	25.1	
P7A	2/16/18	P7 – silver/green/black paint on pipes	1 st floor – NW Hall Center	3.92	No
P7B	2/26/18		1 st floor – Storage Room	1.56	
P7C	2/26/18		1 st floor – Fuel Oil Pump Room #2	5.6	
P8A	2/16/18	P8 – brownish grey paint on large vertical duct (rusty – minimal paint)	1 st floor – N Hall East	6.4	No
P8B	2/16/18		1 st floor – N Hall East	6.8	
P9A	2/16/18	P9 – black paint on lower walls	1 st floor – N Hall Center	9.4	No
P9B	2/16/18		1 st floor – N Hall Center	7.8	

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
P10A	2/19/18	P10 – grey/silver paint on large horizontal duct (10'x4')	1 st floor – Temp Oil Storage Area	6	No
P10B	2/19/18		1 st floor – Fan room	6.32	
P10C	2/19/18		1 st floor – Fan room	6.1	
P11A	2/16/18	P11 – black paint on metal stairs	1 st floor – N Hall	5.03	No
P11B	2/26/18		1 st floor – stairs S of FOPR #2	10.6	
P11C	2/26/18		1 st floor – stairs S of FOPR #2	6.9	
P12A	2/16/18	P12 – dark green paint on lower wall (0'-6')	1 st floor – NE Hall North	6.7	No
P12B	2/16/18		1 st floor – NE Hall Center	4.55	
P12C	2/16/18		1 st floor – NE Hall South	5.92	
P13A	2/16/18	P13 – dark green paint on wood door frame	1 st floor – NE Hall	9	No
P13B	2/26/18		1 st floor – BF Pump Hall window W	4.3	
P14A	2/16/18	P14 – green paint on lower wall (0-6.5')	1 st floor – Bathroom Area North	4	No
P14B	2/16/18		1 st floor – Bathroom Area Center	3.7	
P14C	2/16/18		1 st floor – Bathroom Area South	7.9	
P15A	2/16/18	P15 – white paint on upper wall (6.5' - ceiling)	1 st floor – Bathroom Area	1.29	No
P15B	2/16/18		1 st floor – Bathroom Area	1.11	
P15C	2/16/18		1 st floor – Bathroom Area	2.02	
P16A	2/19/18	P16 – light green/white paint on ceilings of bath areas & upper wall of south bath (6.5'-20')	1 st floor – Bathroom Area ceiling	2.8	No
P16B	2/19/18		1 st floor – Bathroom Area ceiling	2.6	
P16C	2/19/18		1 st floor – Bathroom Area ceiling	3.1	
P17A	2/16/18	P17 – red paint on fire hose wall box & connector pipe	1 st floor – Bathroom Area	31	No
P17B	2/26/18		1 st floor – stairs S of FOPR #2	20.9	
P17C	2/26/18		1 st floor – stairs S of FOPR #2	7.8	
P18A	2/19/18	P18 – silver paint on pipes	1 st floor – NW Hall	8.81	No
P19A	2/19/18	P19 – green paint on metal pipes	1 st floor – Bath	3.68	No
P19B	2/26/18		1 st floor – BF Pump Area N	21.7	

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
P20A	2/21/18	P20 – silver paint on walls	1 st floor – Temp Oil Storage Area West	3.47	No
P20B	2/21/18		1 st floor – Temp Oil Storage Area North	2.97	
P20C	2/21/18		1 st floor – Temp Oil Storage Area East	3.64	
P21A	2/21/18	P21 – yellow paint on brick walls	1 st floor – Fan Room NE	7.2	No
P21B	2/21/18		1 st floor – Fan Room East	5.86	
P21C	2/21/18		1 st floor – Fan Room West	3.87	
P22A	2/21/18	P22 – orange paint on metal fan motors & fan ducts	1 st floor – Fan Room fan motor	6.4	No
P22B	2/21/18		1 st floor – Fan Room fan motor	8.4	
P22C	2/21/18		1 st floor – Fan Room fan duct	4.55	
P23A	2/21/18	P23 – black paint on concrete fan motor pads	1 st floor – Fan Room N fan pad	8.77	No
P23B	2/21/18		1 st floor – Fan Room A-4 fan pad	32.5	
P23C	2/21/18		1 st floor – Fan Room A-39 fan pad	6.5	
P25A	2/21/18	P25 – dark green paint lower wall (CMU, brick)	1 st floor – S Fan Room lower E wall	2.81	No
P25B	2/21/18		1 st floor – SW Hall E wall	5.18	
P25C	2/21/18		1 st floor – SW Hall partition hall	8.45	
P26A	2/21/18	P26 – light green paint upper wall (CMU, brick)	1 st floor – S Fan Room S wall upper	6.59	No
P26B	2/21/18		1 st floor – SW Hall NE corner	8.82	
P26C	2/21/18		1 st floor – SW Hall S wall	6.02	
P27A	2/19/18	P27 – white structural steel	1 st floor – SW Hall	1.67	No
P27B	2/19/18		1 st floor – SW Hall	3.5	
P27C	2/19/18		1 st floor – SW Hall	1.64	
P28A	2/19/18	P28 – white paint on concrete ceiling	1 st floor – SW Hall N	5.05	No
P28B	2/19/18		1 st floor – SW Hall S	4.99	
P29A	2/21/18	P29 – dark blue lower wall	1 st floor – SW Hall Office area East	10.13	No
P29B	2/21/18		1 st floor – SW Hall Office area South	9.49	
P29C	2/21/18		1 st floor – SW Hall Office area West	5.14	

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
P30A	2/21/18	P30 – light blue upper wall & ceiling	1 st floor – SW Hall Office area East	6.2	No
P30B	2/21/18		1 st floor – SW Hall Office area North	4.4	
P30C	2/21/18		1 st floor – SW Hall Office area South	11.4	
P31A	2/26/18	P31 – green paint on metal door/window frames	1 st floor – SW Hall office door frame	10	No
P31B	2/26/18		1 st floor – SW Hall office door frame	10.1	
P32A	2/26/18	P32 – green/red paint on wooden cabinet	1 st floor – SW Hall cabinet	12.8	No
P32B	2/26/18		1 st floor – SW Hall cabinet	13.2	
P33A	2/19/18	P33 – white paint on upper walls & entire south wall	1 st floor – storage room	3.9	No
P33B	2/19/18		1 st floor – storage room	7.6	
P33C	2/19/18		1 st floor – FOPR #2	ND<0.43	
P34A	2/19/18	P34 –gray paint on lower walls/ ceiling	1 st floor – FOPR #2	13.14	No
P34B	2/19/18		1 st floor – gas cylinder room	24.6	
P34C	2/19/18		1 st floor – gas cylinder room	13.41	
P35A	2/19/18	P35 –white paint on upper wall	1 st floor – gas cylinder room	12.37	No
P35B	2/19/18		1 st floor – gas cylinder room	14.99	
P35C	2/19/18		1 st floor – FOPR #2	1.56	
P36A	2/26/18	P36 – red paint on metal doors & frames	1 st floor – Gas Cylinder Room	30	No
P36B	2/26/18		1 st floor – Gas Cylinder Room	39	
P38A	2/26/18	P38 – orange paint on pump valves	1 st floor – Fuel Oil Pump Room #2	54.5	Yes
P38B	2/26/18		1 st floor – Fuel Oil Pump Room #2	13.3	
P39A	2/26/18	P39 – gray paint on concrete pump pads	1 st floor – Fuel Oil Pump Room #2	16.8	No
P39B	2/26/18		1 st floor – Fuel Oil Pump Room #2	16.6	
P39C	2/26/18		1 st floor – Fuel Oil Pump Room #2	18.2	

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
P40A	2/26/18	P40 – red paint on heat exchange pipes	1 st floor – Fuel Oil Pump Room #2	2.56	No
P40B	2/26/18		1 st floor – Fuel Oil Pump Room #2	1.25	
P40C	2/26/18		1 st floor – Fuel Oil Pump Room #2	0.46	
P41A	2/26/18	P41 – peach/gray paint on metal fuel pumps	1 st floor – Fuel Oil Pump Room #2	7.6	No
P41B	2/26/18		1 st floor – Fuel Oil Pump Room #2	5.6	
P42A	2/26/18	P42 – yellow paint on valves	1 st floor – Fuel Oil Pump Room #2	5.9	No
P42B	2/26/18		1 st floor – Fuel Oil Pump Room #2	7.9	
P43A	2/26/18	P43 – white paint upper wall (block)	1 st floor – BF Pump Area E	10.84	No
P43B	2/26/18		1 st floor – BF Pump Area above door	10.04	
P43C	2/26/18		1 st floor – BF Pump Area N	6.17	
P44A	2/26/18	P44 – gray paint lower wall (block)	1 st floor – BF Pump Area N	7.88	No
P44B	2/26/18		1 st floor – BF Pump Area E-wall	10.19	
P44C	2/26/18		1 st floor – BF Pump Room E CTR	6.36	
P45A	2/26/18	P45 – gray paint on concrete pump pads	1 st floor – BF Pump Area CTR	4.37	No
P45B	2/26/18		1 st floor – BF Pump Hall S	22.1	
P45C	2/26/18		1 st floor – BF Pump Hall	10.39	
P46A	2/26/18	P46 – black paint on metal BF pump supports	1 st floor – BF Pump Area S	1.94	No
P46B	2/26/18		1 st floor – BF Pump Area CTR	6.1	
P46C	2/26/18		1 st floor – BF Pump Area W	6.88	
P47A	2/26/18	P47 – orange paint on air compressor	1 st floor – BF Pump Area	10	No
P47B	2/26/18		1 st floor – BF Pump Area	8.4	
P47C	2/26/18		1 st floor – BF pump area N	5.49	

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
P48A	2/28/18	P48 – orange paint on metal tank	1 st floor – Lube Oil Room (Tank SE)	1.39	No
P48B	2/28/18		1 st floor – Lube Oil Room (Tank NE)	2.32	
P49A	2/28/18	P49 paint on metal lube oil containers	1 st floor – Lube Oil Room (Tank NE)	3.29	No
P49B	2/28/18		1 st floor – Lube Oil Room (Tank W)	7.42	
P49C	2/28/18		1 st floor – Lube Oil Room (Tank W)	11.13	
P50A	2/26/18	P50 – gray paint on 18” diameter pipe & tank	1 st floor – BF Pump area C	ND<0.50	No
P50B	2/26/18		1 st floor – BF Pump area C-E	ND<0.49	
P51A	2/26/18	P51 – silver paint on upper block walls & brick at boilers	2 nd floor –North wall NW	1.42	No
P51B	2/26/18		2 nd floor – West wall CTR	3.6	
P51C	2/26/18		2 nd floor – South wall	1.66	
P51D	2/28/18		2 nd floor – Boiler 11	1.0	
P51E	3/1/18		2 nd floor – Boiler 7	ND<0.44	
P51F	3/1/18		North boiler mezzanine	ND<0.43	
P51G	3/1/18		Boiler 4 Mezzanine	ND<0.42	
P51H	3/1/18		Boiler Room staging – east wall	0.59	
P51I	3/1/18		Boiler staging – Boiler 3	ND<0.44	
P52A	2/28/18		P52 – black paint on pipes & valve wheels	2 nd floor – West Seg valve 11	
P52B	2/28/18	2 nd floor – Gen valve #2		9.3	
P52C	2/28/18	2 nd floor – Seg valve 9		10.61	
P53A	2/28/18	P53 – silver paint on structured beams, columns, mezzanine supports, stairs	2 nd floor – Boiler 2	4.36	No
P53B	2/28/18		2 nd floor – Mezzanine beam	3.73	
P53C	2/28/18		2 nd floor – Mezzanine support stairs	2.51	
P53D	2/28/18		2 nd floor – Mezzanine support	0.87	
P53E	3/1/18		Upper BR Mezzanine – steel beam	0.88	
P53F	3/1/18		Staircase to bunker – steel beam	0.60	

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
P54A	2/28/18	P54 – dark green paint on lower block walls (5') - N&S corners & ends	2 nd floor – North wall NW	6.1	No
P54B	2/28/18		2 nd floor – West wall NW	5.6	
P54C	2/28/18		2 nd floor – South wall SW	7.18	
P54D	2/28/18		2 nd floor – East wall	2.8	
P55A	2/28/18	P55 – silver paint on pipes	2 nd floor – West 18” dia exp.	ND<0.47	No
P55B	2/28/18		2 nd floor – 3’ breach West	0.52	
P55C	2/28/18		2 nd floor – 12” West riser	ND<0.49	
P56A	2/28/18	P56 – blue paint on segregation valve	2 nd floor – West	4.82	No
P57A	2/28/18	P57 – black paint on concrete pads beneath motor pumps	2 nd floor – West	3.26	No
P57B	2/28/18		2 nd floor – West	1.5	
P58A	2/28/18	P58 – orange paint on motor pump	2 nd floor – West motor pump	2.2	No
P58B	2/28/18		2 nd floor – West motor pump	2.7	
P59A	3/1/18	P59 – grey paint on tanks	2 nd floor – West Mezzanine paint on tank	ND<0.49	No
P59B	3/1/18		2 nd floor – West Mezzanine paint on tank	ND<0.49	
P59C	3/1/18		2 nd floor – West Mezzanine tank	ND<0.48	
P60A	2/28/18	P60 – green paint on stairs & landings to boiler controls	2 nd floor – Boiler #2 Mezzanine beam	2.5	No
P60B	2/28/18		2 nd floor – Boiler #5 stair rail	3.77	
P60C	2/28/18		2 nd floor – Boiler #12 Mezzanine beam	9.9	
P61A	2/28/18	P61 – white paint on interior of Control Room walls	2 nd floor – Control Room CMU int	8.5	No
P61B	2/28/18		2 nd floor – Control Room CMU int	8.4	
P61C	2/28/18		2 nd floor – Control Room CMU int	12	

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
P62A	2/28/18	P62 – white paint on interior ceiling	2 nd floor – Control Room ceiling	10.1	No
P62B	2/28/18		2 nd floor – Control Room ceiling	13.7	
P62C	2/28/18		2 nd floor – Control Room ceiling	13.7	
P63A	2/28/18	P63 – white paint on exterior walls	2 nd floor – Control Room exterior wall panel	9.45	No
P63B	2/28/18		2 nd floor – Control Room ext wall panel	1.19	
P63C	2/28/18		2 nd floor – Control Room ext wall	6.83	
P64A	2/28/18	P64 – blue paint on walls of lavatory	2 nd floor – lavatory walls	5.3	No
P64B	2/28/18		2 nd floor – lavatory walls	7.1	
P64C	2/28/18		2 nd floor – lavatory walls	6.6	
P65A	2/28/18	P65 – red paint on fire stand pipe	2 nd floor – South West (SE)	9.61	No
P65B	3/1/18		Upper area – Winch Room NE	0.80	
P65C	3/1/18		2 nd floor – East wall fire box NE	1.4	
P66A	2/28/18	P66 – beige paint on ceiling of lavatory	2 nd floor – lavatory ceiling	9.45	No
P66B	2/28/18		2 nd floor – lavatory ceiling	3.9	
P66C	2/28/18		2 nd floor – lavatory ceiling	10.83	
P67A	2/28/18	P67 – beige paint on walls & ceiling in restroom	2 nd floor – Restroom upper wall	3.57	No
P67B	2/28/18		2 nd floor – Restroom lower wall	5.21	
P67C	2/28/18		2 nd floor – Restroom ceiling	3.8	
P68A	3/1/18	P68 – silver/grey ceiling paint on concrete	Upper BR Mezzanine ceiling paint	0.46	No
P68B	3/1/18		Upper BR Mezzanine ceiling paint	ND<0.46	No
P68C	3/1/18		Upper BR Mezzanine ceiling paint	1.23	

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 4
BULK SAMPLE SUMMARY OF SUSPECT PCB CONTAINING MATERIALS
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Sample No.	Sample Date	Homogenous Material Type	Sample Location	Total PCB (ppm)	EPA Regulated (Yes / No)
C1A	3/1/18	C1 – caulk at seams of tanks	2 nd floor – West Mezzanine	ND<0.67	No
C1B	3/1/18		2 nd floor – West Mezzanine	ND<0.79	
C1C	3/1/18		2 nd floor – West Mezzanine	ND<0.78	
DWG1A	2/26/18	DWG1 – light gray hard door window glaze	1 st floor – SW Hall Office	1.1	No
DWG1B	2/26/18		1 st floor – SW Hall west door	ND<0.75	
DWG1C	2/26/18		1 st floor – SW Hall door west wall	ND<0.71	
WG1A	2/26/18	WG1 – interior window on East wall	1 st floor – Storage Room	1.61	No
WG1B	2/26/18		1 st floor – Storage Room	2.37	
WG2A	2/26/18	WG2 – window glaze on interior metal frame windows (east wall)	1 st floor – BF pump area	1.59	No
WG2B	2/26/18		1 st floor – BF pump area	ND<0.74	
WG2C	2/26/18		1 st floor – BF pump area	1.1	
WG3A	2/28/18	WG3 – glazing on interior windows	2 nd floor – Restroom	ND<0.79	No
WG3B	2/28/18		2 nd floor – Restroom	ND<0.67	
WG3C	2/28/18		2 nd floor – Restroom	ND<0.72	
WG4A	3/1/18	WG4 – top of Boiler Room (above bunkers)	Room above bunkers – int dr	ND<0.74	No
WG4B	3/1/18		Room above bunkers – int dr	ND<0.70	
WG5A	2/26/18	WG5 – tan/cream window glaze on interior metal window	1 st floor – BF Pump area	ND<0.79	No
WG5B	2/26/18		1 st floor – BF Pump area	ND<0.78	
WG5C	2/26/18		1 st floor – BF Pump hall	0.92	
1	6/26/18	WG6 – hard tan glaze on interior window	Coal conveyor level - North	ND<0.77	No
2	6/26/18		Coal conveyor level - North	ND<0.70	

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

TABLE 5
IDENTIFIED PCB BULK PRODUCT WASTE (> 50 ppm)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT

Material	Sample Date (mo/yr)	General Location	Estimated Quantity
P38 – orange paint on pump valves	Sampled 02/18	<u>1st floor</u> – Fuel Oil Pump Room #2 <i>(The majority of these pump valves had oil/staining. Spill/contamination is suspected.)</i>	100 SF
P5 - silver/orange paint on structural steel column	Sampled 02/18 & 03/18	<u>1st floor</u> – west wall of fan room (center column) <i>(Only one column had results >50 ppm PCBs. Twelve (12) other samples on columns/structural steel were well below 50 ppm. Future planned sampling of the Fan Room and specifically this column, will be performed to assess for possible liquid PCB releases that may have impacted various surfaces. If appropriate, the waste characterization may be modified if the source of the PCBs is from a liquid release.)</i>	50 SF

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

TABLE 6
IDENTIFIED EXCLUDED PCB PRODUCTS (> 1 ppm)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT

Material	Sample Date (mo/yr)	General Location	Estimated Quantity
FT1 – 9”x9” green floor tile ♦	Sampled 02/18	1 st floor – SW Hall Office	<i>All floor tile (170 SF) removed as part of Interim Measures Project.</i>
FTM1 – black mastic associated with 9”x9” green floor tile ♦	Sampled 02/18	1 st floor – SW Hall Office	<i>All mastic (170 SF) removed as part of Interim Measures Project.</i>
Mastic associated with 12”x12” floor tile (FT2) ♦	Sampled 02/18	2 nd floor – Restroom	<i>All mastic (160 SF) removed as part of Interim Measures Project.</i>
P1 – silver/green paint on lower wall (0-6’)	Sampled 02/18	1 st floor – NW Hall (W & E lower walls), North Hall (N & W lower walls), SW Hall (West wall)	3,220 SF
P2 – silver paint on wall (brick, CMU)	Sampled 02/18	1 st floor – NW Hall (Upper West Wall, South Wall, Partial East Wall), North Hall (Upper West & North Wall), SW Hall (West wall)	6,540 SF
P3 – silver/grey paint on concrete ceiling & metal ceiling (under boilers)	Sampled 02/18	1 st floor – NW Hall	17,000 SF
P5 – silver/orange structural steel components (throughout upper portions & columns)	Sampled 02/18 & 03/18	Throughout 1 st floor	31,100 SF
P5 – silver/orange structural (throughout upper portions & columns) P33 – white paint upper walls & entire South wall	Sampled 02/18 & 03/18	1 st floor – Fuel Oil Pump Room #2	
Oil stain on overhead pipe	Sampled 03/18	1 st floor Fan Room – East wall	2 SF
P6 – silver/green metal door & metal window framing	Sampled 02/18	1 st floor – multiple locations mainly along halls	675 SF
P7 – silver/green/black paint on pipes	Sampled 02/18	1 st floor – throughout	2,000 SF

♦ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

TABLE 6
IDENTIFIED EXCLUDED PCB PRODUCTS (> 1 ppm)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT

Material	Sample Date (mo/yr)	General Location	Estimated Quantity
P8 – brownish grey paint on large vertical duct	Sampled 02/18	1 st floor – North Hall, 2 nd floor – boiler room (north end) <i>(Two vertical ducts run from 1st floor through boiler room to upper floors)</i>	4,750 SF
P9 – black paint on lower walls	Sampled 02/18	1 st floor – North Hall (South walls)	240 SF
P10 – grey/silver paint on large horizontal duct (10'x4')	Sampled 02/18	1 st floor – Temp Oil Storage Room, Fan room, SW Hall	11,500 SF
P11 – black paint on metal stairs	Sampled 02/18	1 st floor – North Hall Stairs, North East Hall Stairs, Stairs in Area South of FOPR#2	270 SF
P12 – dark green paint on lower wall (0'-6')	Sampled 02/18	1 st floor – North Hall (east wall on South end), NE Hall (E,W & partial S walls)	1, 830 SF
P13 – dark green paint on wood door frame	Sampled 02/18	1 st floor – NE Hall (NE door), BF Pump Hall (West window)	40 SF
P14 – green paint on lower wall (0-6.5')	Sampled 02/18	1 st floor – Bathroom Area	970 SF
P15 – white paint on upper wall (6.5'- ceiling)	Sampled 02/18	1 st floor – Bathroom Area	2,020
P16 – light green/white paint on ceilings of bath areas & upper wall of south bath (6.5'- 20')	Sampled 02/18	1 st floor – Bathroom Area, South Bathroom Area	2,070 SF
P17 – red paint on fire hose wall box & connector pipes	Sampled 02/18	1 st floor – Bathroom Area, Area South of FOPR#2	300 SF
P18 – silver paint on pipes	Sampled 02/18	1 st floor – throughout	250 SF
P19 – green paint on metal pipes	Sampled 02/18	1 st floor – Bathroom Area, BF Pump Area	325 SF

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

TABLE 6
IDENTIFIED EXCLUDED PCB PRODUCTS (> 1 ppm)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT

Material	Sample Date (mo/yr)	General Location	Estimated Quantity
P20 – silver paint on walls	Sampled 02/18	1 st floor – Temporary Oil Storage Area	1,020 SF
P21 – yellow paint on brick walls	Sampled 02/18	1 st floor – Fan Room, Temporary Oil Storage Area (NE Corner)	2,480 SF
P22 – orange paint on metal fan motors & fan ducts	Sampled 02/18	1 st floor – Fan Room (6 units)	2,700 SF
P23 – black paint on concrete fan motor pads	Sampled 02/18	1 st floor – Fan Room (6 units)	1,500 SF
P25 – dark green paint lower wall (CMU, brick)	Sampled 02/18	1 st floor – South Fan Room, SW Hall (N,S & E walls), SW Hall Restroom, Area South of FOPR#2	3,140 SF
P26 – light green paint upper wall (CMU, brick)	Sampled 02/18	1 st floor – South Fan Room, SW Hall (N,S & E walls), SW Hall Restroom, Area South of FOPR#2	7,250 SF
P27 – white structural steel	Sampled 02/18	1 st floor – SW Hall	900 SF
P28 – white paint on concrete ceiling	Sampled 02/18	1 st floor – SW Hall	3,330 SF
P29 – dark blue lower wall	Sampled 02/18	1 st floor – SW Hall office & office 2	350 SF
P30 – light blue upper wall & ceiling	Sampled 02/18	1 st floor – SW Hall office & office 2	590 SF
P31 – green paint on metal door/window frames	Sampled 02/18	1 st floor – SW Hall - office, office 2, bathroom,	85 SF
P32 – green/red paint on wooden cabinet	Sampled 02/18	1 st floor – SW Hall	100 SF

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 6
IDENTIFIED EXCLUDED PCB PRODUCTS (> 1 ppm)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Material	Sample Date (mo/yr)	General Location	Estimated Quantity
P33 – white paint on walls/ceilings	Sampled 02/18	1 st floor – Storage Room (upper walls & entire south wall, ceiling), FOPR2 (upper N,S,W walls, structural steel, ceiling)	5,350 SF
P34 –gray paint on walls/ceiling	Sampled 02/18	1 st floor – gas cylinder (lower walls, ceiling), FOPR2 (lower N,S,W walls, east wall)	2,560 SF
P35 –white paint on upper wall	Sampled 02/18	1 st floor – gas cylinder (upper walls), FOPR2 (east wall)	2,430 SF
P36 – red paint on metal doors & frames	Sampled 02/18	1 st floor – Gas Cylinder Room	70 SF
P39 – gray paint on concrete pump pads	Sampled 02/18	1 st floor – Fuel Oil Pump Room #2	200 SF
P40 – red paint on heat exchange pipes	Sampled 02/18	1 st floor – Fuel Oil Pump Room #2	2,000 SF
P41 – peach/gray paint on metal fuel pumps	Sampled 02/18	1 st floor – Fuel Oil Pump Room #2	300 SF
P42 – yellow paint on valves	Sampled 02/18	1 st floor – Fuel Oil Pump Room #2	10 SF
P43 – white paint on upper block wall (6.5' – 20')	Sampled 02/18	1 st floor – BF Pump Area, BF Pump Hall	5,190 SF
P44 – gray paint on lower block wall (0' - 6.5')	Sampled 02/18	1 st floor – BF Pump Area, BF Pump Hall	2,500 SF
P45 – gray paint on concrete pump pads	Sampled 02/18	1 st floor – BF Pump Area, BF Pump Hall	1,150 SF
P46 – black paint on metal BF pump supports	Sampled 02/18	1 st floor – BF Pump Area	300 SF
P47 – orange paint on air compressor	Sampled 02/18	1 st floor – BF Pump Area	200 SF (2 compressors)

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 6
IDENTIFIED EXCLUDED PCB PRODUCTS (> 1 ppm)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Material	Sample Date (mo/yr)	General Location	Estimated Quantity
P48 – orange paint on metal tank	Sampled 02/18	1 st floor – Lube Oil Room	270 SF (2 tanks – one is 90% rust)
P49 paint on metal lube oil containers	Sampled 02/18	1 st floor – Lube Oil Room	560 SF (9 containers)
P51 – silver paint on upper block/brick walls & brick/metal on boilers 1-12	Sampled 02/18	2 nd floor – upper walls, boilers throughout and upper elevated areas	56,600 SF
P52 – black paint on pipes & valve wheels	Sampled 02/18	2 nd floor – West Seg valve 11, Gen valve #2, Seg valve 9	350 SF
P53 – silver paint on structured beams, columns, mezzanine supports, stairs	Sampled 02/18 & 3/18	Throughout 2 nd floor and upper elevated areas	29, 640 SF
P54 – dark green paint on lower block walls (5')	Sampled 02/18	2 nd floor – North & South walls and corner areas	1,400 SF
P56 – blue paint on segregation valve	Sampled 02/18	2 nd floor – along West Wall	50 SF
P57 – black paint on concrete pads beneath motor pumps	Sampled 02/18	2 nd floor – along West & North Wall	50 SF
P58 – orange paint on motor pump	Sampled 02/18	2 nd floor – along West Wall	50 SF
P60 – green paint on stairs & landings to boiler controls	Sampled 02/18	2 nd floor – center row between boilers	1,920 SF (on all boilers)
P61 – white paint on interior of Control Room walls	Sampled 02/18	2 nd floor – Control Room CMU int	385 SF
P62 – white paint on interior ceiling	Sampled 02/18	2 nd floor – Control Room ceiling	260 SF
P63 – white paint on exterior walls	Sampled 02/18	2 nd floor – Control Room exterior wall panel	400 SF

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

TABLE 6
IDENTIFIED EXCLUDED PCB PRODUCTS (> 1 ppm)
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT

Material	Sample Date (mo/yr)	General Location	Estimated Quantity
P64 – blue paint on walls of lavatory	Sampled 02/18	2 nd floor – LAV walls	800 SF
P65 – red paint on fire stand pipe	Sampled 02/18 & 03/18	Throughout 2 nd floor – fire boxes/stand pipes	200 SF
P66 – beige paint on ceiling of lavatory	Sampled 02/18	2 nd floor – LAV ceiling	260 SF
P67 – beige paint on walls & ceiling in restroom	Sampled 02/18	2 nd floor – Restroom	610 SF
P68 – silver/grey ceiling paint on concrete	Sampled 03/18	Mezzanine Level - Ceiling	28,420 SF
DWG1 – light gray hard door window glaze	Sampled 02/18	1 st floor – SW Hall, NW Hall,	9 EA
WG1 – interior window on East wall	Sampled 02/18	1 st floor – Storage Room (east wall)	1 EA
WG2 – window glaze on interior metal frame windows (east wall)	Sampled 02/18	1 st floor – BF pump Area (East Wall – Center Area)	3 EA

◆ Asbestos containing material (ACM) (>1%) or inseparable from an adjacent ACM

**TABLE 7
INVENTORY OF ADDITIONAL HAZARDOUS/REGULATED
MATERIALS, WASTES AND ITEMS IDENTIFIED
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Quantity	Size	Material/Item	General Location	Potential Hazard
1	-	Thermostat	1 st floor - rooms off northwest hall	Universal Waste (UW)
6	-	Mercury pressure gauge	1 st floor – BF Pump Area	Universal Waste (UW)
4	-	Motors units		Connecticut Regulated Waste
1	-	Venture pressure meter		Universal Waste (UW)
1	-	Mercury pressure gauge	1 st floor - lube oil room	Universal Waste (UW)
9	-	Oil reservoirs		Connecticut Regulated Waste
1	-	Tank		Connecticut Regulated Waste
18	-	Light bulbs		Light bulbs w/ ampoules
1	-	Emergency lighting		Universal Waste (UW)
3	-	Mercury pressure gauge		1 st floor - northwest hall
2	-	Mercury lamp	Universal Waste (UW)	
1	-	Halogen bulb	Universal Waste (UW)	
3	-	Fluorescent bulbs	Universal Waste (UW)	
3	-	Ballast	Connecticut Regulated Waste	
6	-	Light bulbs	Light bulbs w/ ampoules	
8	-	U-shaped fluorescent	1 st floor - rooms off northwest hall	Universal Waste (UW)
5	-	Ballasts		Connecticut Regulated Waste
5	-	Fluorescent bulbs		Universal Waste (UW)
1	-	Emergency lighting		Universal Waste (UW)
3	-	Mercury lamp	1 st floor - north center hall	Universal Waste (UW)
7	-	Motor fan units		Connecticut Regulated Waste
7	-	Mercury pressure gauge		Universal Waste (UW)
4	-	Fluorescent bulb		Universal Waste (UW)
18	-	Light bulb		Universal Waste (UW)
90	-	Pressure gauge	2 nd floor – boiler #1-12 area	Universal Waste (UW)
48	-	Oil filters		Connecticut Regulated Waste
12	-	Motor pumps		Connecticut Regulated Waste
24	-	Control panels		Universal Waste (UW)
72	-	Mercury ampoules		Universal Waste (UW)

- CRW- Connecticut Regulated Waste – PCBs (CR01), Oils (CR02/CR03), waste chemical liquids - antifreeze, latex & solvent paints, sludges, etc. (CR04), waste chemical solids (CR05)
- UW- Universal Waste (batteries, thermostat ampoules, fluorescent lamps, used electronics)
- IH- Inhalation hazard (silicas, etc.)
- I- Ignitable - may contain ingredients which are ignitable (materials which have a flashpoint <140°F) (D001)
- C- Corrosive - may contain ingredients which are alkaline or acidic (materials with a PH<2 or >12.5) (D002)
- T- Toxic - may contain ingredients which are harmful if swallowed or which release vapors that can cause irritation
- R- Reactive – may contain ingredients which are unstable, react violently with water or are explosive (D003)

**TABLE 7
INVENTORY OF ADDITIONAL HAZARDOUS/REGULATED
MATERIALS, WASTES AND ITEMS IDENTIFIED
ENGLISH STATION – BOILER 1-12 INTERIOR
NEW HAVEN, CONNECTICUT**

Quantity	Size	Material/Item	General Location	Potential Hazard
3	-	Fluorescent bulb	2 nd floor – boiler #1-12 area – east side	Universal Waste (UW)
2	-	Ballast		Connecticut Regulated Waste
2	-	Fan motor		Connecticut Regulated Waste
1	-	Thermostat		Universal Waste (UW)
3	-	Mercury ampule		Universal Waste (UW)
2	-	Pressure gauge		Universal Waste (UW)
215	-	Pressure gauges	2 nd floor – boiler #1-12 area – center	Universal Waste (UW)
22	-	Lights w/ ampoules		Universal Waste (UW)
1	-	Fire extinguisher		Miscellaneous
2	-	Monitor		Universal Waste (UW)
2	-	Fan unit		Connecticut Regulated Waste
19	-	Motors		2 nd floor – boiler #1-12 area – west side
3	-	Pressure gauge	Universal Waste (UW)	
3	-	Capacitor	Connecticut Regulated Waste	
3	-	Light bulbs ampoule	Universal Waste (UW)	
1	-	Transformer	Connecticut Regulated Waste	
1	-	Thermostat	Universal Waste (UW)	
8	-	Ballasts	2 nd floor – boiler #1-12 area – NW room to Turbine Hall	Connecticut Regulated Waste
16	-	Fluorescent bulbs		Universal Waste (UW)
12	-	Mechanical boxes	2 nd floor – boiler #1-12 area – diamond plating / north stairs and grating	Universal Waste (UW)
11	-	Light bulbs		Universal Waste (UW)
2	-	Aerosol can		I
24	-	Light bulbs	2 nd floor – boiler #1-12 area – north upstairs room and conveyor room	Universal Waste (UW)
6	-	Motors		Connecticut Regulated Waste
1	-	Ballast		Connecticut Regulated Waste
2	-	Fluorescent bulbs		Universal Waste (UW)
8	-	Pressure gauge	2 nd floor – boiler #1-12 area – western tanks and vat room	Universal Waste (UW)
2	-	Vat motors		Connecticut Regulated Waste
1	-	Light bulbs		Universal Waste (UW)

- CRW- Connecticut Regulated Waste – PCBs (CR01), Oils (CR02/CR03), waste chemical liquids - antifreeze, latex & solvent paints, sludges, etc. (CR04), waste chemical solids (CR05)
- UW- Universal Waste (batteries, thermostat ampoules, fluorescent lamps, used electronics)
- IH- Inhalation hazard (silicas, etc.)
- I- Ignitable - may contain ingredients which are ignitable (materials which have a flashpoint <140°F) (D001)
- C- Corrosive - may contain ingredients which are alkaline or acidic (materials with a PH<2 or >12.5) (D002)
- T- Toxic - may contain ingredients which are harmful if swallowed or which release vapors that can cause irritation
- R- Reactive – may contain ingredients which are unstable, react violently with water or are explosive (D003)



Table 8 - Lead Based Paint Measurement Summary Table

Device(s):	Niton XLP301-A (Serial #25555) X Ray Fluorescence (XRF) Spectrum Analyzer											
Site:	English Station (Boiler 1-12 Interior), 458 Grand Avenue, New Haven, Connecticut											
Project # :	263951-0000-0000											
Date(s):	5/15/18, 5/22/18-5/23/18											
Inspector:	Gregory Kaczynski											
Number	Room	Side	Structure	Feature	Material	Color	Condition	Reading (mg/cm2)	Precision (mg/cm2)	Depth Index	Duration (sec)	Date/Time
1	Shutter calibration											
2	0.3 calibration											
3	1.6 calibration											
4	0.7 calibration											
FIRST FLOOR												
5	BF Pump area		Pad		Concrete	Grey	Intact	0.2	0.0	1.46	12.64	5/15/2018 12:18
6	BF Pump area		Door		Metal	Green	Intact	6.8	1.4	1.46	5.58	5/15/2018 12:19
7	BF Pump area	A	Door		Metal	Green	Intact	6.7	1.6	1.61	4.57	5/15/2018 12:19
8	BF Pump area	A	Wall		Brick	Green	Intact	0.1	0.0	1.56	21.83	5/15/2018 12:21
9	BF Pump area	--	Motor		Metal	Yellow	Intact	0.5	0.1	1.32	5.55	5/15/2018 12:24
10	BF Pump area	A	Wall	Stair	Concrete	Green	Intact	0.0	0.0	1.13	21.27	5/15/2018 12:26
11	BF Pump area	--	Door for stair	Casing	Metal	Green	Intact	2.4	0.3	1.77	4.06	5/15/2018 12:29
12	BF Pump area	--	--	Pipe	Metal	Red	Intact	0.1	0.0	1.73	8.63	5/15/2018 12:30
13	BF Pump area	--	Pad		Metal	Black	Intact	0.0	0.0	1.08	6.6	5/15/2018 12:32
14	BF Pump area	--	Pad		Metal	Black	Intact	0.6	0.1	1.1	5.07	5/15/2018 12:33
15	BF Pump area	--	Pad	--	Concrete	Grey	Intact	0.2	0.0	1.7	30	5/15/2018 12:34
16	BF Pump area	--	Pad	--	Concrete	Grey	Intact	0.3	0.0	1.82	30	5/15/2018 12:34
17	BF Pump area	--	Column	--	Metal	Grey	Intact	8.7	1.6	3.27	5.6	5/15/2018 12:36
18	BF Pump area	B	Wall	--	Block	Grey	Intact	0.2	0.0	1.78	21.77	5/15/2018 12:39
19	NW Hall	D	Wall	--	Block	Silver	Intact	0.5	0.1	1.28	5.06	5/15/2018 12:46
20	NW Hall	D	Wall	--	Block	Silver	Intact	0.4	0.1	1.27	16.15	5/15/2018 12:46
21	NW Hall	B	Wall	--	Brick	Silver	Intact	1.4	0.4	1.45	30	5/15/2018 12:47
22	NW Hall	B	Column	--	Metal	Silver	Intact	8.3	1.4	1.91	6.58	5/15/2018 12:48
23	NW Hall	A	Large filters (loose)	--	Metal	White	Intact	0.0	0.0	1.1	4.56	5/15/2018 12:51
24	NW Hall	A	Wall	--	Brick	Silver	Intact	0.0	0.0	1	8.08	5/15/2018 12:55
25	0.3 calibration											
26	0.7 calibration											
27	3.5 calibration											
28	Shutter calibration											
29	0.3 calibration											
30	1.6 calibration											
31	0.7 calibration											
32	1.0 calibration											
33	Temporary Oil Storage area	D	Wall		Brick	Grey	Intact	0.9	0.1	1.09	20.63	5/23/2018 9:42
34	Temporary Oil Storage area	B	Column		Metal	Yellow	Intact	8.1	2.8	1.95	3.12	5/23/2018 9:43
35	Temporary Oil Storage area	D	Door	Casing	Metal	Green	Intact	0.3	0.1	1.01	2.65	5/23/2018 9:44
36	Fan Room	B	Wall	--	Brick	Yellow	Intact	1.6	0.3	1.18	3.11	5/23/2018 9:44
37	Fan Room	--	Fan motor #2	--	Metal	Orange	Intact	3.2	0.7	1.89	2.63	5/23/2018 9:46

Lead paint includes paint found to contain **any detectable** amount of lead by Atomic Absorption Spectrophotometry (AAS) or X-Ray Fluorescence (XRF).

Side A = Street side; Sides B,C,D follow clockwise



Table 8 - Lead Based Paint Measurement Summary Table

Number	Room	Side	Structure	Feature	Material	Color	Condition	Reading (mg/cm2)	Precision (mg/cm2)	Depth Index	Duration (sec)	Date/Time
Device(s): Niton XLP301-A (Serial #25555) X Ray Fluorescence (XRF) Spectrum Analyzer Site: English Station (Boiler 1-12 Interior), 458 Grand Avenue, New Haven, Connecticut Project # : 263951-0000-0000 Date(s): 5/15/18, 5/22/18-5/23/18 Inspector: Gregory Kaczynski												
38	Fan Room	--	Fan motor #3	Base	Concrete	Grey	Intact	0.0	0.0	1	4.28	5/23/2018 9:47
39	Fan Room	--	Fan #4	--	Metal	Orange	Intact	1.6	0.3	1.15	3.11	5/23/2018 9:48
40	Fan Room	D	Column	--	Metal	Orange	Intact	11.8	3.8	1.74	2.38	5/23/2018 9:49
41	Fan Room	--	Fan #5	--	Concrete	Grey	Intact	0.1	0.0	1.04	5	5/23/2018 9:50
42	Fan Room	--	Fan #5	--	Metal	Orange	Intact	3.3	0.6	1.44	2.4	5/23/2018 9:51
43	VOID		VOID		VOID			VOID				VOID
44	Fan Room	--	Fan #5	Motor	Metal	Orange	Intact	0.2	0.1	1.58	3.58	5/23/2018 9:52
45	Fan Room	--	Pipe (near fan #5)	--	Metal	Rust	Intact	0.0	0.0	4.19	5.97	5/23/2018 9:54
46	Fan Room	--	Pipe (near fan #5)	--	Metal	Rust	Intact	0.0	0.0	2.04	2.85	5/23/2018 9:54
47	Fan Room	B	Wall	--	Brick	Yellow	Intact	2.1	0.3	1.31	3.34	5/23/2018 9:56
48	Fan Room	C	Wall	--	Brick	Grey	Intact	0.0	0.0	1	3.1	5/23/2018 9:56
49	Fan Room	C	Wall	Lower	Brick	Grey	Intact	1.4	0.2	1.18	3.57	5/23/2018 9:57
50	Fan Room	B	Column	--	Metal	Yellow	Intact	7.0	3.4	1.8	2.16	5/23/2018 9:58
51	South Fan Room	B	Wall	Upper	cmu	Light green	Intact	0.1	0.0	1.59	7.18	5/23/2018 10:00
52	VOID		VOID		VOID			VOID				VOID
53	South Fan Room	B	Wall	Lower	cmu	Dark green	Intact	0.1	0.0	2.27	8.12	5/23/2018 10:01
54	South Fan Room	B	Door	--	Metal	Dark green	Intact	1.8	0.2	1.64	3.83	5/23/2018 10:02
55	VOID		VOID		VOID			VOID				VOID
56	South Fan Room	C	Door	Casing	Metal	Dark green	Intact	1.6	0.2	1.33	5.03	5/23/2018 10:03
57	SW Hall	D	Wall	--	Block	Dark green	Intact	0.4	0.1	1.6	4.29	5/23/2018 10:05
58	SW Hall	D	Wall	Upper	Block	Light green	Intact	0.1	0.0	1.21	4.3	5/23/2018 10:05
59	SW Hall	C	Wall	Upper	Block cmu	Light green	Intact	0.1	0.0	1.87	4.76	5/23/2018 10:06
60	SW Hall	C	Wall	Lower	Block cmu	Dark green	Intact	0.0	0.0	2.69	4.08	5/23/2018 10:08
61	VOID		VOID		VOID			VOID				VOID
62	SW Hall	B	Column	--	Metal	Orange	Intact	3.3	0.6	1.43	2.39	5/23/2018 10:10
63	SW Hall - Office	A	Wall	Upper	cmu	Blue	Intact	0.3	0.1	2.51	4.53	5/23/2018 10:11
64	SW Hall - Office	--	Ceiling	--	Metal	White	Intact	0.0	0.0	1.46	3.58	5/23/2018 10:12
65	SW Hall - Office	D	Window	Casing	Metal	White	Intact	2.5	0.5	2.01	3.32	5/23/2018 10:13
66	SW Hall - Office	D	Door	Casing	Metal	White	Intact	1.4	0.2	1.4	4.08	5/23/2018 10:13
67	Stairwell (South of SW Hall)	A	Door	Casing	Metal	Orange	Intact	0.7	0.1	1.33	4.07	5/23/2018 10:16
68	Stairwell (South of SW Hall)	A	Door	--	Metal	Orange	Intact	0.0	0.0	1.54	4.77	5/23/2018 10:16
69	Stairwell (South of SW Hall)	D	Wall	Lower	Block	Green	Intact	0.1	0.0	1.49	4.78	5/23/2018 10:17
70	NW Hall	D	Wall	Lower	Block	Grey	Intact	0.4	0.1	1.26	5.01	5/23/2018 10:20
71	NW Hall	D	Pipe	--	Metal	Grey	Intact	0.4	0.1	1.38	3.81	5/23/2018 10:20
72	NW Hall	D	Door	--	Metal	Green	Intact	0.1	0.0	1.1	4.31	5/23/2018 10:21
73	NW Hall	B	Pipe rack	--	Metal	Rust	Intact	0.0	0.0	1.3	3.59	5/23/2018 10:23
74	NW Hall	B	Pipe rack	--	Metal	Rust	Intact	0.0	0.0	1.47	2.88	5/23/2018 10:23
75	NW Hall	B	Pipe rack	--	Metal	Rust	Intact	0.0	0.0	1	3.82	5/23/2018 10:24

Lead paint includes paint found to contain **any detectable** amount of lead by Atomic Absorption Spectrophotometry (AAS) or X-Ray Fluorescence (XRF).

Side A = Street side; Sides B,C,D follow clockwise



Table 8 - Lead Based Paint Measurement Summary Table

Number	Room	Side	Structure	Feature	Material	Color	Condition	Reading (mg/cm2)	Precision (mg/cm2)	Depth Index	Duration (sec)	Date/Time
Device(s): Niton XLP301-A (Serial #25555) X Ray Fluorescence (XRF) Spectrum Analyzer Site: English Station (Boiler 1-12 Interior), 458 Grand Avenue, New Haven, Connecticut Project # : 263951-0000-0000 Date(s): 5/15/18, 5/22/18-5/23/18 Inspector: Gregory Kaczynski												
76	BF Pump Area	B	Pipe (near pump #4)	--	Metal	Rust	Intact	0.0	0.0	2.05	3.12	5/23/2018 10:25
77	BF Pump Area	--	Pipe (near pump #5)	--	Metal	Rust	Intact	0.0	0.0	1	3.36	5/23/2018 10:26
78	Lube Oil Room	B	Column	--	Metal	Black	Intact	1.1	0.1	1.55	10.08	5/23/2018 10:30
79	Lube Oil Room	B	Tank	--	Metal	Black	Intact	0.3	0.1	1	7.4	5/23/2018 10:31
80	Lube Oil Room	B	Wall	--	Block	Grey	Intact	0.1	0.0	1.15	5.49	5/23/2018 10:39
SECOND FLOOR												
81	Boiler #1-12 area	D	Wall	--	Block	Silver	Intact	0.0	0.0	1.15	5.27	5/23/2018 10:45
82	Boiler #1-12 area	D	Breeching	--	Metal	Silver	Intact	0.3	0.1	3.87	5.27	5/23/2018 10:46
83	Boiler #1-12 area	D	Stair	--	Metal	Silver	Intact	1.1	0.1	1.32	8.61	5/23/2018 10:47
84	Boiler #1-12 area	--	Beam	--	Metal	Silver	Intact	4.9	0.9	1.51	2.39	5/23/2018 10:49
85	Boiler #1-12 area-by Boiler #4	D	Boiler	Wall	Brick	Silver	Intact	0.0	0.0	1.35	5.03	5/23/2018 10:50
86	Boiler #1-12 area-by Boiler #4	D	Boiler	Column	Metal	Silver	Intact	0.1	0.0	1.15	5.02	5/23/2018 10:51
87	Boiler #1-12 area	A	Wall	Upper	Block	Silver	Intact	0.1	0.0	1	4.55	5/23/2018 10:52
88	Boiler #1-12 area	A	Wall	Lower	Block	Black	Intact	0.6	0.1	1.31	5.04	5/23/2018 10:53
89	Boiler #1-12 area-by Boiler #2	--	Wall	Boiler	Brick	Silver	Intact	0.0	0.0	1	3.34	5/23/2018 10:54
90	Boiler #1-12 area-by Boiler #2	--	Wall column	Boiler	Brick	Silver	Intact	0.2	0.1	1.29	3.83	5/23/2018 10:55
91	Boiler #1-12 area-by Boiler #2	--	Column	--	Metal	Orange	Intact	10.0	3.2	1.79	2.88	5/23/2018 10:56
92	Boiler #1-12 area-by Boiler #2		Boiler landing	Column	Metal	Green	Intact	0.3	0.1	1.15	4.53	5/23/2018 10:57
93	Boiler #1-12 area-by Boiler #11		Boiler landing	Column	Metal	Green	Intact	0.5	0.1	1.01	2.87	5/23/2018 10:58
94	Boiler #1-12 area-by Boiler #2		Boiler plate	--	Metal	Green	Intact	1.7	0.3	1.29	3.11	5/23/2018 10:59
95	VOID		VOID		VOID			VOID				VOID
96	Boiler #1-12 area-by Boiler #11		Boiler plate	--	Metal	Green	Intact	1.0	0.1	1.43	20.49	5/23/2018 11:01
97	VOID		VOID		VOID			VOID				VOID
98	Boiler #1-12 area		Wall	Upper	Brick	Silver	Intact	0.0	0.0	1.56	5.51	5/23/2018 11:03
99	Boiler #1-12 area		Wall	Lower	Brick	Green	Intact	1.4	0.1	1.22	8.14	5/23/2018 11:04
100	Boiler #1-12 area	--	Column	--	Metal	Green	Intact	12.3	2.0	2.26	3.83	5/23/2018 11:05
101	Boiler #1-12 area-Lavatory	A	Wall	--	Concrete	Blue	Intact	13.6	1.9	7.56	4.56	5/23/2018 11:06
102	Boiler #1-12 area-Lavatory	B	Wall	--	Brick	Blue	Intact	9.4	1.9	6.49	3.34	5/23/2018 11:08
103	VOID		VOID		VOID			VOID				VOID
104	Boiler #1-12 area-Lavatory	D	Door	Casing	Metal	Blue	Intact	0.2	0.1	6.22	4.77	5/23/2018 11:09
105	Boiler #1-12 area-Lavatory	--	Ceiling	--	Concrete	Green	Intact	11.4	4.0	3.61	2.14	5/23/2018 11:10
106	Boiler #1-12 area-by Boiler #7	B	Window	--	Metal	Silver	Intact	0.1	0.0	1.09	4.08	5/23/2018 11:12
107	Boiler #1-12 area-by Boiler #7	B	Window	--	Metal	Silver	Intact	0.4	0.1	1.15	5.49	5/23/2018 11:13
108	Boiler #1-12 area-by Boiler #9	B	Window	--	Metal	Silver	Intact	0.2	0.1	1.25	3.1	5/23/2018 11:14
109	Boiler #1-12 area-by Boiler #9	D	Boiler	Wall	Brick	Silver	Intact	0.0	0.0	1	5.98	5/23/2018 11:16
110	Boiler #1-12 area-by Boiler #11	D	Boiler	Wall	Brick	Silver	Intact	0.0	0.0	1.61	4.06	5/23/2018 11:17
111	Boiler #1-12 area-by Boiler #9	D	Boiler	Column	Metal	Silver	Intact	0.4	0.1	1.33	6.21	5/23/2018 11:18
112	Boiler #1-12 area-by Boiler #11	--	Boiler	Column	Metal	Silver	Intact	1.2	0.1	1.62	5.26	5/23/2018 11:18

Lead paint includes paint found to contain **any detectable** amount of lead by Atomic Absorption Spectrophotometry (AAS) or X-Ray Fluorescence (XRF).

Side A = Street side; Sides B,C,D follow clockwise



Table 8 - Lead Based Paint Measurement Summary Table

Number	Room	Side	Structure	Feature	Material	Color	Condition	Reading (mg/cm2)	Precision (mg/cm2)	Depth Index	Duration (sec)	Date/Time
Device(s): Niton XLP301-A (Serial #25555) X Ray Fluorescence (XRF) Spectrum Analyzer Site: English Station (Boiler 1-12 Interior), 458 Grand Avenue, New Haven, Connecticut Project # : 263951-0000-0000 Date(s): 5/15/18, 5/22/18-5/23/18 Inspector: Gregory Kaczynski												
113	Boiler #1-12 area-by Boiler #9	--	Boiler	Column	Metal	Silver	Intact	0.3	0.1	1.85	3.34	5/23/2018 11:19
114	Boiler #1-12 area-by Boiler #9	B	Wall	Upper	Brick	Silver	Intact	0.0	0.0	1.09	3.58	5/23/2018 11:20
115	Boiler #1-12 area-by Boiler #9	B	Wall	Lower	Brick	Green	Intact	0.4	0.1	1.07	4.06	5/23/2018 11:20
116	Boiler #1-12 area-by Boiler #11	C	Wall	Lower	Brick	Green	Intact	1.4	0.2	1.13	3.59	5/23/2018 11:22
117	Boiler #1-12 area-by Boiler #11	C	Wall	Upper	Brick	Silver	Intact	0.0	0.0	1	3.58	5/23/2018 11:23
118	VOID		VOID		VOID			VOID				VOID
119	Boiler #1-12 area-by Boiler #11	C	Beam	Upper	Metal	Orange	Intact	0.1	0.0	1.2	4.3	5/23/2018 11:25
120	Boiler #1-12 area-by Boiler #11	C	Str	Rail	Metal	Green	Intact	1.4	0.1	1.22	5.02	5/23/2018 11:26
121	Boiler #1-12 area-by Boiler #11	C	Column	Rail	Metal	Black	Intact	7.8	1.8	1.77	3.36	5/23/2018 11:27
122	Boiler #1-12 area-by Boiler #11	--	Boiler plate	Loose	Metal	Silver	Intact	0.2	0.1	1.25	3.11	5/23/2018 11:29
123	Boiler #1-12 area-by Boiler #11	--	Boiler plate	Loose	Metal	Silver	Intact	0.1	0.0	1	3.83	5/23/2018 11:29
124	VOID		VOID		VOID			VOID				VOID
125	Boiler #1-12 area-by Boiler #12	--	Boiler landing	Beam	Metal	Green	Intact	0.7	0.2	1.26	3.36	5/23/2018 11:30
126	Boiler #1-12 area-by Boiler #11	--	Boiler landing	Beam	Metal	Green	Intact	0.2	0.1	1	3.6	5/23/2018 11:31
127	Boiler #1-12 area-corner duct	--	Corner duct	--	Metal	Grey	Intact	2.1	0.4	1.55	2.88	5/23/2018 11:32
128	VOID		VOID		VOID			VOID				VOID
129	Boiler #1-12 area	D	Wall	--	Block	Silver	Intact	0.0	0.0	1.02	2.87	5/23/2018 11:37
130	Boiler #1-12 area	D	Pipe	--	Metal	Rust	Intact	0.5	0.2	1.21	2.15	5/23/2018 11:39
131	Boiler #1-12 area	D	Pipe	--	Metal	Rust	Intact	0.0	0.0	1	2.87	5/23/2018 11:40
132	Boiler #1-12 area	D	Pipe	--	Metal	Rust	Intact	0.0	0.0	1.85	3.82	5/23/2018 11:41
133	Boiler #1-12 area	D	Pipe	--	Metal	Rust	Intact	0.0	0.0	1.05	5.03	5/23/2018 11:46
134	Boiler #1-12 area-Mezzanine	--	tank	--	Metal	White	Intact	0.0	0.0	1.49	3.84	5/23/2018 11:49
135	Boiler #1-12 area - stairs	B	Wall (to 1st floor)	--	Concrete	Green	Intact	0.4	0.1	1.22	3.82	5/23/2018 11:53
136	0.3 calibration	--	--	--		Green	Intact	0.3	0.0	1.05	7.65	5/23/2018 13:30
137	0.7 calibration	--	--	--		Green	Intact	0.6	0.1	1	5.24	5/23/2018 13:30
138	1.6 calibration	--	--	--		Green	Intact	1.6	0.1	1.18	5.76	5/23/2018 13:30
139	Boiler #1-12 area north -stairwell	--	stair	--	Metal	Silver	Intact	0.3	0.1	1.02	4.07	5/23/2018 13:52
ELEVATED AREAS - NORTH END												
140	Boiler #1-12 area north	--	blr column	--	Metal	Silver	Intact	0.6	0.1	1.79	3.35	5/23/2018 13:54
141	Boiler #1-12 area north - Room 1	B	Window	--	Metal	Black	Intact	4.4	0.8	1.45	2.39	5/23/2018 13:57
142	Boiler #1-12 area north - Room 1	D	Column	--	Metal	Black	Intact	7.2	2.8	2.22	2.88	5/23/2018 13:58
143	West Coal Bunker Mech Room	--	Beam	--	Metal	Black	Intact	1.8	0.4	1.29	2.87	5/23/2018 14:00
144	West Coal Bunker Mech Room	B	Door	--	Metal	Black	Intact	1.5	0.2	1.77	3.58	5/23/2018 14:00
145	West Coal Bunker Mech Room	A	Window	--	Metal	Black	Intact	6.9	2.8	2.47	2.88	5/23/2018 14:01
146	VOID		VOID		VOID			VOID				VOID
147	West Coal Bunker Mech Room	B	Wall	--	Brick	Silver	Intact	0.1	0.0	1.28	6.46	5/23/2018 14:02
148	Boiler #1-12 area north -elevated stairwell	--	duct	--	Metal	Silver	Intact	0.4	0.1	1.18	4.06	5/23/2018 14:06
149	Boiler #1-12 area north -elevated stairwell	A	pipe	--	Metal	Green	Intact	0.1	0.1	1.63	3.1	5/23/2018 14:07

Lead paint includes paint found to contain **any detectable** amount of lead by Atomic Absorption Spectrophotometry (AAS) or X-Ray Fluorescence (XRF).

Side A = Street side; Sides B,C,D follow clockwise



Table 8 - Lead Based Paint Measurement Summary Table

Device(s):	Niton XLP301-A (Serial #25555) X Ray Fluorescence (XRF) Spectrum Analyzer											
Site:	English Station (Boiler 1-12 Interior), 458 Grand Avenue, New Haven, Connecticut											
Project # :	263951-0000-0000											
Date(s):	5/15/18, 5/22/18-5/23/18											
Inspector:	Gregory Kaczynski											
Number	Room	Side	Structure	Feature	Material	Color	Condition	Reading (mg/cm2)	Precision (mg/cm2)	Depth Index	Duration (sec)	Date/Time
150	Boiler #1-12 area north -elevated stairwell	D	Wall	--	Brick	Silver	Intact	0.0	0.0	1.56	4.09	5/23/2018 14:09
151	Boiler #1-12 area 5th level (steel plates)	--	Ceiling	Beam	Metal	Silver	Intact	7.8	3.4	2.17	2.16	5/23/2018 14:12
152	Boiler #1-12 area 5th level (steel plates)	--	Ceiling	Beam	Metal	Silver	Intact	5.6	2.8	1.65	2.39	5/23/2018 14:13
153	Boiler #1-12 area 5th level (steel plates)	--	Ceiling	Beam	Metal	Silver	Intact	9.0	3.4	1.62	2.4	5/23/2018 14:13
154	VOID		VOID		VOID			VOID				VOID
155	Boiler #1-12 area 5th level (steel plates)	--	Ceiling	--	Concrete	Silver	Intact	0.0	0.0	1.6	5.25	5/23/2018 14:15
156	Boiler #1-12 area 5th level (steel plates)	--	Railing	--	Metal	Rust	Intact	0.5	0.1	1.34	4.07	5/23/2018 14:17
157	Boiler #1-12 area north -elevated stairwell	--	boiler plate loose	--	Metal	Silver	Intact	0.0	0.0	1	2.63	5/23/2018 14:24
158	Boiler #1-12 area north -elevated stairwell	--	Pipe	--	Metal	rust	Intact	0.0	0.0	1.14	3.84	5/23/2018 14:26
159	1.6 calibration	--	--	--	--			1.5	0.1	1.12	5.26	5/23/2018 14:55
160	0.3 calibration	--	--	--	--			0.3	0.1	1.09	2.87	5/23/2018 14:55
161	0.7 calibration	--	--	--	--			0.7	0.1	1.09	9.08	5/23/2018 14:56

Lead paint includes paint found to contain **any detectable** amount of lead by Atomic Absorption Spectrophotometry (AAS) or X-Ray Fluorescence (XRF).

Side A = Street side; Sides B,C,D follow clockwise

PHOTOS



PHOTO 1 – 2nd Floor Boiler 1-12 Area – View of Boiler Ribs



PHOTO 2 – 2nd Floor Boiler 1-12 Area – Elevated Area between Boilers



PHOTO 3 – 1st Floor NW Hall – Facing South



PHOTO 4 – Coal Conveyor Level Area – Facing North



PHOTO 5 – 1st Floor BF Pump Area – Facing South



PHOTO 6 – 2nd Floor Boiler 1-12 Area – East Side – Facing South




PHOTO 7 – 2nd Floor Boiler 1-12 Area – West Side – Facing South



PHOTO 8 – 2nd Floor Boiler 1-12 Area – Center Area Between Boilers – Facing South



PHOTO 9 – 1st Floor Fan Room – Facing South



PHOTO 10 – 1st Floor – Former Temporary Oil Storage Area – Facing South



PHOTO 11 – 1st Floor Fan Room – Silver/Orange Paint (P5) on Column with PCB Bulk Sample Results >50 ppm



PHOTO 12 – 1st Floor Fuel Oil Pump Room #2 – Orange Paint (P38) on Pump Valves with PCB Bulk Sample Results >50 ppm



PHOTO 13 – 1st Floor Fuel Oil Pump Room #2 – Orange Paint (P38) on Pump Valves with PCB Bulk Sample Results >50 ppm

ASBESTOS AND PCB INSPECTION FIGURES

APPENDICES

APPENDIX A
LABORATORY ACCREDITATIONS

State of Connecticut, Department of Public Health
Approved Environmental Laboratory

THIS IS TO CERTIFY THAT THE LABORATORY DESCRIBED BELOW HAS BEEN APPROVED BY THE STATE DEPARTMENT OF PUBLIC HEALTH PURSUANT TO APPLICABLE PROVISIONS OF THE PUBLIC HEALTH CODE AND GENERAL STATUTES OF CONNECTICUT, FOR MAKING THE EXAMINATIONS, DETERMINATIONS OR TESTS SPECIFIED BELOW WHICH HAVE BEEN AUTHORIZED IN WRITING BY THAT DEPARTMENT.

TRC ENVIRONMENTAL CORPORATION

LOCATED AT 21 Griffin Road North IN Windsor, CT 06095

AND REGISTERED IN THE NAME OF Erik Plimpton

THIS CERTIFICATE IS ISSUED IN THE NAME OF Kathleen Williamson WHO HAS BEEN DESIGNATED BY THE REGISTERED OWNER/AUTHORIZED AGENT TO BE IN CHARGE OF THE LABORATORY WORK COVERED BY THIS CERTIFICATE OF APPROVAL AS FOLLOWS:


**BUILDING MATERIALS
ASBESTOS FIBERS - PCM
BULK IDENTIFICATION - PLM**

SEE COMPUTER PRINT-OUT FOR SPECIFIC TESTS APPROVED

EFFECTIVE RENEWAL DATE JANUARY 1, 2018

THIS CERTIFICATE EXPIRES DECEMBER 31, 2019 AND IS REVOCABLE FOR CAUSE BY THE STATE DEPARTMENT OF PUBLIC HEALTH

DATED AT HARTFORD, CONNECTICUT, THIS 19th DAY OF December, 2017



Registration
No.

PH-0426

SUZANNE BLANCAFLOR, MS, MPH
CHIEF, ENVIRONMENTAL HEALTH SECTION



STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH SECTION



ENVIRONMENTAL LABORATORY CERTIFICATION PROGRAM CERTIFIED ANALYTES REPORT FOR ALL MATRICES

TRC-Environmental Corporation

21 GRIFFIN ROAD NORTH
WINDSOR, CT 060951590

CT REGISTRATION NUMBER :

REGISTERED OWNER / AUTHORIZED AGENT : Erik Plimpton

DIRECTOR : Kathleen Williamson

CO DIRECTOR(S) :

PHONE : (860) 298-9692

LABORATORY REGISTRATION EFFECTIVE DATE :

LABORATORY REGISTRATION EXPIRATION DATE :

LABORATORY STATUS :

APPROVED BY

SUZANNE BLANCAFLOR, MS, MPH
CHIEF, ENVIRONMENTAL HEALTH SECTION

REVIEWED BY

12/19/2017 11:00:24 AM

DERMOT JONES

ANY QUESTIONS CONCERNING THIS DOCUMENT SHOULD BE ADDRESSED TO THE
ENVIRONMENTAL LABORATORY CERTIFICATION PROGRAM AT (860) 509-7389

**CONSTRUCTION, RENOVATION & DEMO BLDG
MATERIALS**

STATUS REPORTED ON 12/19/2017

ANALYTE NAME

ASBESTOS

ASBESTOS FIBERS (PCM)

ASBESTOS IN BULK MATERIALS (PLM)